

General Contractor/Installer

Project Name

Project Location

Observer's Name

Jobsite Superintendent

Date of Observation

#	ITEM	YES	NO	N/A
<b>STORAGE</b>				
1	LP WeatherLogic® sheathing stored off the ground, well supported, on a flat surface and under wrap or under a roof	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Units not stacked more than four high	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Panel Storage Location: <input type="checkbox"/> Under Roof <input type="checkbox"/> Inside/Conditioned <input type="checkbox"/> Outside Covered <input type="checkbox"/> Other _____			
<b>WALL INSTALLATION</b>				
1	Blue water-resistive overlay facing to the exterior	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	All LP WeatherLogic® sheathing installed with a minimum 1/8" spacing between panels	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Minimum 1/2" gap observed between bottom edge of panel and foundation	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Used minimum 6d (2" x 0.131" diameter) common nails for panels up to 1/2" thick and 8d (2-12" x 0.131" diameter) common nails for panels up to 5/8" thick	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Nails driven 3/8" from panel edges	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Panel edge nails spaced as specified (maximum 6" o.c.)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Panel field nail spaced as specified (maximum 12" o.c.)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	Nails driven flush	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	All overdriven nails and shiners covered with a 4" length of LP WeatherLogic® Seam & Flashing Tape or a 1" diameter patch of LP WeatherLogic® Seam & Flashing Sealant or other AAMA 714-certified liquid-applied flashing	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	All seams covered with LP WeatherLogic® Seam & Flashing Tape or Sealant as soon as conditions permit after nailing inspections	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Minor chips, cuts and scratches covered with LP WeatherLogic® Seam & Flashing Tape or Sealant extending 2" past the chip, cut or scratch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	LP WeatherLogic® wall system covered by exterior cladding before 6 months	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>ROOF INSTALLATION</b>				
1	Roof slope is 2:12 or greater	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Blue water-resistive overlay facing to the exterior	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	All LP WeatherLogic® sheathing installed with a minimum 1/8" spacing between panels	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Use minimum 8d (2-1/2" x 0.131" diameter) common nails	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Nails driven 3/8" from panel edges	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Nails spaced 6" o.c. along panel edges (tighter nail spacing may be required)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Nails spaced 12" o.c. in the field (tighter nail spacing may be required)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

#	ITEM	YES	NO	N/A
<b>ROOF INSTALLATION (CONTINUED)</b>				
8	Nails driven flush	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	All overdriven nails and shiners covered with a 4" length of LP WeatherLogic® Seam & Flashing Tape or a 1" diameter patch of LP WeatherLogic® Seam & Flashing Sealant or other AAMA 714-certified liquid-applied flashing	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	All seams covered with LP WeatherLogic® Seam & Flashing Tape or Sealant as soon as conditions permit after nailing inspections	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Minor chips, cuts and scratches covered with LP WeatherLogic® Seam & Flashing Tape or Sealant extending 2" past the chip, cut or scratch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	LP WeatherLogic® roof system covered by roof cladding within 6 months	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>TAPE AND/OR SEALANT</b>				
1	Only LP WeatherLogic® Seam & Flashing Tape or Sealant was used to seal panel joints on this job	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Tape installed when ambient temperature was above 10° F and panel surface temperature was below 130° F	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Sealant applied in temperatures above 0° F	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Tape or sealant applied to clean, dry surface that is free from frost	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Finished sealant extends 1-3/4" wide on each side of seam and 1-1/4" past nail heads	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Proper tape lapping or shingling was observed	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Proper pressure was applied to tape using supplied squeegee or other approved device	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8	When extending a run of tape, new run overlaps previous run by minimum of 2"	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>WINDOWS &amp; DOORS</b>				
1	Door side jams are taped with at least 2" of tape width extending onto panel	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Jam and head flanges are taped covering the flange fasteners and extending at least 2" onto the panel surface	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Vertical seam tape above an opening is shingled over the head flange tape	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	If used at head of door or window, drip edge fasteners are covered and tape extends at least 2" onto the face of the panel	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Bottom nail flange not taped to allow drainage	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>PENETRATIONS</b>				
1	Penetrations are flashed using proper shingling techniques	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Products used to flash penetrations: _____			

**NOTES:**

---



---



---

This checklist is only a supplement to the LP WeatherLogic® Air & Water Barrier Installation Manual. It does not replace a thorough understanding of the installation instructions. When a conflict exists between this checklist and the LP WeatherLogic® Air & Water Barrier Installation Manual, the Installation Manual prevails.