

Declaration of Performance.

0832-CPR-0617


0832-CPD-0617

Product Type	PNS-0001		
Type	NEXUS 105 DC SOUNDER ONLY (TYPE B)		
Intended Use	Fire detection and fire alarm systems installed in and around buildings.		
Manufacturer :	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW		
Placed on market	Texecom Ltd. Bradwood Court, St Crispin Way, Haslingden, Lancashire. BB4 4PW.		
System of assessment	System 1		
Notified Body	BRE Global Limited		
Accreditation Number	0832		
Type Testing	EN54-3:2001+A1:2002+A2:2006 – Fire detection and fire alarm systems – Fire alarm devices – Sounders.		
EC certificate of conformity	0832-CPD-0617		
Declared Performance			
Essential Characteristics	EN54-3 Subclause		Type B
Reproducibility	5.2		Pass
Operational performance	5.3		Pass
Durability	5.4		Pass
Dry Heat (operational)	5.5		Pass
Dry Heat (endurance)	5.6		Pass
Cold (operational)	5.7		Pass
Damp heat, cyclic (operational)	5.8		Pass
Damp heat, steady state (endurance)	5.9		Pass
Damp Heat, cyclic (endurance)	5.10		Pass
SO2 corrosion (endurance)	5.11		Pass
Shock (operational)	5.12		Pass
Impact (operational)	5.13		Pass
Vibration (operational)	5.14		Pass
Vibration (endurance)	5.15		Pass
Electrostatic discharge (operational)	5.16		Pass
Radiated electromagnetic fields (operational)	5.16		Pass
Voltage transients, fast transient bursts (operational)	5.16		Pass
Enclosure Protection	5.17		Pass

The performance of the product identified in Product Type and Type above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of Texecom Limited

Signed for and on behalf of the manufacturer by:

Name: Hugh Devereux Head of Approvals & Compliance



Place and date if issue: 11/03/2015