



RFP QUESTIONS & ANSWERS SUMMARY (PART 2)

RFP # PGE01-GID55-SH-001 - Engineering Design for the Summit-Meadows Wildfire Mitigation UG Conversion Project

RFP QUESTIONS			RFP RESPONSES		
#	Supplier Question	Question Date	PGE Responses	Answer Date	RFP or SOW Update Required (Y/N)
69	SOW Section 7.3.4, Page 9 (60% Design Package - Plan-and-Profile Drawings) Section 7.3.4 requires "<i>plan-and-profile drawings identifying the vertical alignment of the proposed facilities.</i>" Please clarify whether a typical trench detail with standard or assumed burial depths will satisfy this requirement, or whether PGE expects the profile drawings to reflect actual existing ground elevations along the full project alignment. If actual elevations are required, please confirm whether the selected Contractor is expected to obtain an existing-conditions topographic survey to develop the profile drawings, or whether PGE will provide elevation data as part of the survey support referenced in Q&A Nos. 9 and 39 and Amendment No. 2, revised SOW § 6.1.12. If this level of detail is required only for specific portions of the project, please identify the applicable segments and define the expected scope.	9/24/2026	Actual existing ground elevations along the full project alignment are not required for this purpose. Site-specific elevation details will be provided by PGE where a crossing requires a nonstandard depth. Unless otherwise directed by PGE, proposed designs should assume compliance with PGE's standard depth requirements.	9/30/2026	N