

Integrated Resource Planning

ROUNDTABLE 22-9 OCTOBER 2022





ANE BON

MEETING LOGISTICS



Electronic version of presentation:

<u>https://www.portlandgeneral.com/our-company/energy-</u> <u>strategy/resource-planning/integrated-resource-planning/irp-public-</u> <u>meetings</u>

Teams Meeting

Join on your computer or mobile app Click here to join the meeting



Or join by entering a meeting ID Meeting ID: 215 719 845 007 Passcode: LzjEQe

Or call in (audio only) <u>+1 971-277-2317,,233287942#</u> United States, Portland Phone Conference ID: 299 540 974#

Please use Microsoft Edge or Google Chrome with Teams as it will give you the best experience



PARTICIPATION

During the presentation



All attendees will be muted; to unmute yourself via computer, click on the microphone that appears on the screen when you move your mouse



To unmute yourself over the phone, press *6



If you call in using your phone in addition to joining via the online link, please make sure to **mute your computer** audio



Use the chat feature to share your comments and questions.



Raise your hand icon to let us know you have a question

Interaction Agreements



We will ask for comments and questions along the way



Please be polite and respect all participants on the webinar



Please stay on topic; we may interrupt or shorten questions to meet the time commitment of the meeting

3

AGENDA

8:30 – 8:40 Welcome and Introductions

8:40 - 8:45 Safety Moment

8:45 – 10:00 Transmission Part II

10:00 - 11:00 PGE Climate Change Resource Planning Study

11:00 – 11:15 Resource Adequacy

11:15 - 11:45 Flexibility Analysis

12:15 – 12:30 Clean Energy Plan Information



SAFETY MOMENT

Emergency Preparedness



Do one thing a month to have a safety plan in place



Replace smoke alarm batteries yearly



Buy a gallon of water at your next grocery trip or boil a gallon of water and seal in a clean container



Create a communication plan with your community









IRP ANALYSIS PROCESS



IRP Roundtable 10/26/2022

TRANSMISSION PART II

ROB CAMPBELL, Principal Strategy & Planning Analyst Integrated Resource Planning JACOB GOODSPEED, Principal Energy Supply Procurement Originator Renewable Initiatives ROUNDTABLE 22-9

Transmission in the 2023 IRP

Existing

New

2030/2040	PGE/BPA interface	Future transmission development
	Assess existing transmission rights on BPA system, find ways to increase interface, open new scheduling points of strategic relevance.	Continue to plan for 2040 system needs collaboratively with Northern Grid, regional RA partners, and remaining engaged with merchant developers.
	Treatment in IRP to be discussed today.	For discussion in a future roundtable.
	PGE Transmission Planning	Regional opportunities
	Planning to WECC and NERC standards for PGE system upgrades and interface with BPA.	Continue to assess and pursue commercial opportunities for existing transmission projects that would expand PGE's transmission footprint and provide
	Existing transmission planning process outcomes highlighted in IRP.	a benefit to customers.
Near-term		

Reliability-driven

Affordability-driven

PGE's "four quadrants" transmission approach adds optionality within the IRP



Outline and highlights of today's discussion

Transmission options for IRP consideration Existing system and rights PGE prioritizing system connectivity that could Recognizes constraints on BPA's provide reliability benefit, resource diversity benefit, system and in the BPA/PGE interface and that would supplement existing reach. Assumes TSRs included in cluster Generic transmission option available for portfolio studies in 2021 and earlier can selection. be awarded firm service Transmission option in modeling generally Assumes no incremental BPA corresponds to regional transmission buildout that firm rights after 2021 TSEP could provide optionality to PGE. IRP may select PGE/BPA projects that would increase capacity on South of Allston, West of Cascades South

EXISTING TRANSMISSION SYSTEM

ROB CAMPBELL ROUNDTABLE 22-9





Available transmission: methodology update

Previous Methodology

- Discussed at the April 2020, March 2021, and August 2022 roundtable meetings
- Utilized posted BPA ATC data to determine transmission capacity
 - ✓ Overstated availability by not accounting for allocations awarded since last updates

New Method

- Review BPA's 2016-2021 TSEPs
 - ✓ "Study" TSRs get CF
 - ✓ "Confirmed" TSRs get LTF
- TSRs made prior to the 2022 TSEP that point to PGE's system are likely to be granted conditional firm.
- BPA states that TSRs made starting in 2022 would only be granted service once upgrades are complete.



Available transmission: inventories update



BPA TSEP: https://www.bpa.gov/energy-and-services/transmission/acquiring-transmission/tsep

Resource Zones	Conditional Firm (MW)	Long-Term Firm (MW)	Total (MW)
Gorge	388	190	578
Montana *	0	0	0
SE Washington	150	0	150
Offshore	80	0	80
Christmas Valley	510	490	1000
Willamette Valley	0	10	10

* 100 MW of conditional firm to MT pointed at PGE, but contingent on \$1.2 billion in upgrades and 2030 energization date.

IRP Roundtable 10/26/2022

Curtailment potential represents risk

Point-to-Point (long-term firm)

690 MW available in aggregate, not including the 2022 TSEP, from all resource zones per existing transmission service requests.

Service is for transfer of energy and capacity from Point of Receipt to Point of Delivery.

Can potentially be redirected and/or resold.

Takes priority over conditional firm and other non-firm products.

No additional capacity available.

Conditional firm

1128 MW available in aggregate, not including the 2022 TSEP, from all resource zones per existing transmission service requests.

Subset of point-to-point transmission that allows BPA to curtail service. This potential curtailment introduces operational and regulatory risks for PGE's customers.

Curtailment can be to relieve system congestion (up to a certain number of hours per year) or to resolve system needs. BPA retains discretion to curtail PGE service per BPA's tariff.

No additional capacity available until upgrades are in service.

IRP Roundtable 10/26/2022

TRANSMISSION PATH OPTIONS

JACOB GOODSPEED ROUNDTABLE 22-9





Generic versus specific projects in IRPs

Our IRPs use 'proxy' resources that



Have general technological capabilities that are available through public sources (e.g., wind turbine size, hub height)



Represent behavior within a geographic area (e.g., Columbia Gorge)



Are subject to locational transmission constraints



Serve as a placeholder for market availability, which will be determined as part of procurement.



Less information would lead to an <u>unactionable plan</u>

More information would create an <u>overly prescriptive</u> <u>and inflexible plan</u>

The IRP estimates the costs and benefits associated with each of these proxy resources when determining actions



Approach to transmission expansion

Our capacity expansion model (ROSE-E) will assume the availability of additional transmission capacity expansion options after 2026:

Path	Resource	Energy and capacity assumption
Generic proxy transmission (Tx Proxy)	Desert SW Solar (DSW) Wyoming wind (WY) Dispatchable Capacity	 Model can select to "build" a transmission path to access resource profiles based on climate zones in the WECC. Transmission resource assumed to be able to access Desert Southwest solar, Wyoming wind, dispatchable capacity, or a combination of resource options. Transmission cost, resource and capacity cost, energy and capacity benefits of will each be evaluated by ROSE-E
South of Allston Expansion (SOA)	IRP proxy resource	Assumes the ability to increase transfer capacity on PGE's share of South of Allston via upgrade available in 2027. Would unlock additional capacity for resources that leverage BPA rights to get to PGE's system.

IRP Roundtable 10/26/2022

Transmission option modeling

Currently, ROSE-E can add proxy generation resources (or market transactions) that utilize assumed available BPA transmission to transport PNW proxy resources to load.



Once BPA rights are exhausted per slide 13, ROSE-E will need to pair a generic transmission proxy (GTP) with incremental proxy generation. Transmission availability is otherwise constrained.



Access to wind via transmission

East to west transmission could provide access to renewables off-system in in climate zones where wind has high production.

PGE will allow the model to choose this climate zone and associated transmission as the Wyoming wind and proxy capacity generic transmission option.

Current projects in development would add capacity to the Oregon Gorge and/or to Central Oregon. Regional need to solve for "last mile" across BPA.

Projects shown at right are indicative only. Path studied to access resources in the IRP will be generic.



Access to solar via transmission

Desert Southwest transmission access could unlock solar resources that are somewhat uncorrelated from PGE production and load.

PGE will allow the model to choose this climate zone and associated proxy transmission as the DSW solar and proxy capacity generic transmission option.

Current projects in development could reach PGE's system through Central Oregon or through COI. Regional need to solve for "last mile" across BPA.

Projects shown at right are indicative only. Path studied to access resources in the IRP will be generic.



IRP Roundtable 10/26/2022

CLIMATE ADAPTATION STUDY

ANDRES ALVAREZ, CREATIVE RENEWABLE SOLUTIONS ROUNDTABLE 22-9





1. Review of Climate Change in Pacific Northwest IRP Planning

2. Climate Change Modeling & Applications to Resource Planning

3. Incorporating Climate Change into PGE's IRP Framework

4. Recommendations



Observable Climate Change Effects



June 29, 2021 temperature compared with the 2014–2020 average for that day

- > PGE Peak demand reached 4,441 megawatts on 06/28/21.
- This heat event is currently estimated to occur only once every 1000 years (1.2°C of global warming). [1]
 - Would occur roughly every 5 to 10 years in a future world with 2°C of global warming [1]

"The Pacific Northwest episode was so extreme that it did not fit our standard modeling approaches. To put this into human terms, this event should not have been possible."

 Flavio Lehner, Cornell Professor in the College of Agriculture and Life Sciences, discussing June 2021 Pacific Northwest heat wave.



Climate Change Impacts in the Pacific Northwest





Climate Impacts on the Power Grid

Energy Demand

- Higher summer temperatures drive increasing cooling demand (electric)
- Higher winter temperatures reduce demand for heating (electric, gas)

Electric Transmission

 Increased heat reduces TX capacity
 Extreme weather (storms, wildfires) can cause additional forced outages to TX and substation infrastructure.

Hydro Power

- Earlier snowmelt shifts peak production earlier in the year.
- Drought and reduced runoff reduce power production.



Renewables & Storage

- Shifts in wind speeds and patterns impact wind generation.
- Increasing solar radiation and temperatures impact solar generation.
- Warming temperatures can impact RT efficiency of storage.

Thermal Generation

- Higher air and water temperatures reduce fuel conversion efficiency and cause nameplate capacity deratings.
- Reduced water availability for cooling can lead to shutoffs (FOR).



PNW Utility Review of Climate Change Impacts - I

Utility	Source	Load & Gen Climate Risks in IRP			Notes:
PGE	2016 PGE IRP – Climate Study	Electric Demand	Solar Gen	Thermal Gen	Climate change scenario analysis of load forecast based 20 CMIP5 models from the Oregon Climate Change
		Hydro Gen	Wind Gen	Storage	Research institute Report (OCCRI). Hydro streams and wind impact were also reviewed in OCCRI report.
PSE	2021 PSE IRP	Electric Demand	Solar Gen	Thermal Gen	PSE used three NPCC and BPA climate models to create future temperature and load scenarios.
		Hydro Gen	Wind Gen	Storage	
AVISTA	2021 Avista IRP	Electric Demand	Solar Gen	Thermal Gen	Avista used three state-level NPCC climate forecasts to
		Hydro Gen	Wind Gen	Storage	create a climate scenario for load and hydro.
	2019 PacifiCorp IRP	Electric Demand	Solar Gen	Thermal Gen	PacifiCorp uses a climate forecast from a 2016 US Bureau of Reclamation study to create a climate
		Hydro Gen	Wind Gen	Storage	scenarios for load and hydro conditions. Discussion on potential impact to solar/wind.
NorthWestern [®] Energy	N/A	Electric Demand	Solar Gen	Thermal Gen	Public comments in IRP process regarding incorporating
		Hydro Gen	Wind Gen	Storage	climate change. No references in 2020 IRPs.
An IDACORP Company	2021 Idaho Power IRP	Electric Demand	Solar Gen	Thermal Gen	References BPA RMJOC climate study. Models a "climate change scenario" with an increased demand
		Hydro Gen	Wind Gen	Storage	forecast associated with extreme temperature events. Climate scenarios used not explicitly discussed.
	RMJOC I & II (2010-2018)	Electric Demand	Solar Gen	Thermal Gen	Joint study with Army Corp where 80 climate scenarios
		Hydro Gen	Wind Gen	Storage	were used to investigate impact on PNW hydro.
Seattle City Light	2016 IRP	Electric Demand	Solar Gen	Thermal Gen	Used 20 climate models to determine impact climate
		Hydro Gen	Wind Gen	Storage	change on hydro and load.



PNW Utility Review of Climate Change Impacts - II



© 2022 Creative Renewable Solutions, LLC.

PUBLIC

NOTE: **PGE values based on 2016 IRP study.** PSE values based on 2021 IRP (does not include 2023 IRP workshop material).



PNW Utility Review of Climate Change Impacts - III

Seasonal shifts in Oregon peak demand observed in PGE and PacifiCorp climate sensitivity scenarios (despite different set of climate ensembles utilized).

- Compared to 2030 base case, PAC and PGE summer peak increases by 2.7% and 3.9%, respectively.
- Compared to 2030 base case, PAC and PGE winter peak decreases by 1.3% and 2.7%, respectively.



PUBLIC



PNW Utility Review of Climate Change Impacts - IV

Average annual hydro generation increases 2.4% in 30-yr climate scenario avg. vs 90-yr historical. Average summer hydro gen decreases 8.5%, while average winter hydro gen increases 6.3%.







PNW Utility Review of Climate Change Impacts - V

Average annual hydro generation increases 3.3% in 30-yr climate scenario avg. vs 30-yr historical. Average summer hydro gen decreases 5.0%, while average winter hydro gen increases 8.0%.



BPA Federal 14 Projects: 30-Yr Historical (1989-2018) vs 30-Yr Climate Forecast (2020-2050)

© 2022 Creative Renewable Solutions, LLC.



PNW Utility Review of Climate Change Impacts - VI



© 2022 Creative Renewable Solutions, LLC.

PUBLIC

Note: Includes hydro data for projects beyond BPA 14 Federal on slides 8 and 9. Climate scenario data is average of four climate models.



PNW Utility Review of Climate Change Impacts - VII



PUBLIC

Note: Includes hydro data for projects beyond BPA 14 Federal on slides 8 and 9. Climate scenario data is average of four climate models.





1. Review of Climate Change in Pacific Northwest IRP Planning

2. Climate Change Modeling & Applications to Resource Planning

3. Incorporating Climate Change into PGE's IRP Framework

4. Recommendations



Climate Change Modeling vs Energy Resource Modeling



Credit: https://doi.org/10.1016/j.joule.2022.05.010.



Climate Modeling Process





Climate Change Impacts on Utility Planning




A new component of future IRP planning



Credit: https://doi.org/10.1016/j.joule.2022.05.010.





1. Review of Climate Change in Pacific Northwest IRP Planning

2. Climate Change Modeling & Applications to Resource Planning

3. Incorporating Climate Change into PGE's IRP Framework

4. Recommendations



PGE's Existing IRP Structure





PGE Climate Sensitivity Approach



- Initial focus of the 2023 PGE IRP climate sensitivity scenario is on the Sequoia model.
 - Focus initially on utilizing climate adjusted hydro and load profiles.
 - Test the two climate adjustments separately first (isolate impact) and then jointly (determine if impact is additive, compounding, etc.)

Leverage same four climate change scenarios as used in the most recent climate change studies issued by BPA and the NWPCC.

1.CanESM2-MACA-PRMS-P1: Warm and wettest scenario.

2.MIROC5-BCSD-VIC-P3: Near the median temperature projection; just above median precipitation above Grand Coulee, but below median precipitation in the Snake River basin.

3.HadGEM2-CC-MACA-VIC-P1: Warmer scenario; median precipitation above Grand Coulee, but above the median precipitation in the Snake River basin.

4.GFDL-BCSD-VIC-P2: One of the coolest and driest scenarios.

Note: Hydro generation & flow data acquired from BPA. Climate temperature data acquired separately.

*	ト	Creative
		Renewable
		Solutions

PGE Heating Degree Days





PGE Cooling Degree Days



PUBLIC

Seasonal Change PGE Hydro Generation



- On June 6, 2022, BPA released a letter recommending the use of a smaller subset of hydro data (1989-2018) for their future resource planning studies.
- BPA expects that the recent 30-year subset will better capture observed and emerging climate change trends.
- For PGE's sequoia model, a subset of hydro years will need to be selected. Impact on PGE's hydro generation will vary depending on whether:
 - A 30-year "historical" data set is used exclusively (1989-2018)
 - A hybrid historical-climate data set is used (2003-2035)
 - A climate data set is used exclusively (2020-2050).



Preliminary Findings

Load Forecast

- Under the climate scenarios, PGE annual HDD peak <u>decreases 3.7%</u> and the average HDD <u>decreases 5.6%</u>.*
- PGE annual CDD peak <u>increases 7.2%</u> and the average CDD <u>increases 7.0%</u>.*

Hydro Generation Forecast

- Under the climate scenarios, PGE's annual hydro generation <u>increases 5.6%.*</u>
- Impact on PGE hydro generation will vary depending on the climate model tested, the hydro facility, and the season.
- Generally, across the climate models, a decrease in hydro generation is seen in August.



1. Review of Climate Change in Pacific Northwest IRP Planning

2. Climate Change Modeling & Applications to Resource Planning

3. Quantifying Climate Change Impact for Load & Generation

4. Incorporating Climate Change into PGE's IRP Framework

5. Recommendations







Recommendations

Recommendations:

- For the 2023 Portland General Electric IRP, the company should focus on performing a preliminary Sequoia study to quantify the impact of climate change forecasts on PGE's load, hydro generation, and peak need.
 - CRS has been actively working with PGE's IRP team to provide the necessary data for this initial analysis.
 - First Sequoia runs underway.
- Beyond the 2023 Portland General Electric IRP, the company should continue to develop internal modeling capabilities in order to generate climate change adjusted wind, solar, and thermal generation forecasts.
 - Data concurrency in IRP modeling should remain an important priority. However, additional work will be required to reconcile data concurrency between stochastic and deterministic models.
- Portland General Electric should also continue to engage in Bonneville Power Authority's climate change modeling workshops and proceedings. Specifically, PGE should ensure that BPA refines the hydro modeling to include PGE specific hydro facilities in the Willamette Basin.
- Portland General Electric should establish a benchmarking mechanism for actual resource generation compared to the climate change adjusted forecast to actively track the forecasting error for future IRPs (narrowing of climate ensembles tested).
- Portland General Electric consider staffing a climate scientist <u>within</u> the Integrated Resource Planning team in order to perform the following functions:
 - Provide additional context for the various climate change forecasts and maintain the company informed of climate risks to both transmission and generation assets (flooding, wildfires, storms, etc).
 - Generate ensemble of climate forecasts (temperature, radiation, wind, precipitation) for PGE's service territory load zones and generation
 assets.
 - Collaborate with IRP team to generate "energy modeling ready" data for load and resource generation forecasts.
 - Manage benchmarking of actual resource generation versus climate forecasted generation.

RESOURCE ADEQUACY MODEL CHANGES & CLIMATE SENSITIVITIES

TOMÀS MORRISSEY, Principal Integrated Resource Planning Analyst

ROUNDTABLE 22-9





Sequoia 101 (the Adequacy Model)

Sequoia is stochastic adequacy model. It simulates load and resource combinations to answer two primary questions:

How much capacity do we need to keep the system adequate?

How much capacity do resources provide to the system?

The model was developed following the 2019 IRP and was used in the 2019 IRP Update and in the ongoing 2021 RFP. Sequoia is PGE's long term planning model rather than an operations model.



What inputs are changing and why

Reducing the number of temperature and hydro years in the model to better capture recent weather events.

- For temperatures, the Corporate Load Forecast uses trended temperature data that are mostly in the range of the four climate models reviewed for the IRP. We will continue to use that forecast but shorten the number of weather years in Sequoia.
- For hydro, the IRP will include sensitivities using climate change model hydro data. For the reference case, we will update from the 1929-2007 record to the 1989-2018 record.
- PGE will continue to evaluate using climate change model data for future planning work.

Increasing light-load-hour (10 PM to 6 AM, Sunday's, and holidays) market availability to provide more energy for storage to charge.



Draft results from July 2022 roundtable

Values here, and throughout this presentation, are for year 2026 reference case (does not include contract renewals)

	Year 2026 ca (M	apacity need W)
	Summer	Winter
July 2022 draft need results	761	863



Temperature years vs. model inputs

Corporate load forecast IRP team has a 42-year creates monthly values hourly load record using trended based on neural net and actual loads (on an temperature data annual energy basis the loads are similar across the 42-years) Sequoia loads start with the 42-year hourly record. The record is scaled up/down to For the 2023 IRP, we start with the scaled 42match the corporate year load record but only allow the model to forecast for monthly select from the most recent 30-years. peak and energy.

-IRP Roundtable 10/26/2022 5

Using fewer temperature years

Switching from 42 to 30 temperature years (1992 – 2021) in the model **increases summer need and decreases winter need.**

	Year 2026 capacity impact (MW)							
	Summer	Winter						
July 2022 draft need results	761	863						
Switch to 30 temp years	62 ↑	(34)↓						

Impacts shown are individual and marginal, not cumulative



Sequoia hydro years

Sequoia historically has pulled from a 79-year (1929 – 2007) hydro record, new data from BPA are now available that run through 2018. Switching to 30 year (1989-2018) hydro record for 2023 IRP.

We are planning to run hydro sensitivities using data from the four climate change models reviewed by Creative Renewable Solutions.

RP Roundtable

Using fewer hydro years

Switching from 79 to 30 hydro years in the					
model increases summer need and					
decreases winter need.					

	Year 2026 capacity impa (MW)						
	Summer	Winter					
July 2022 draft need results	761	863					
Switch to 30 temp years	62 ↑	(34)↓					
Switch to 30 hydro years	13 ↑	(3)↓					

Impacts shown are individual and marginal, not cumulative



Increasing LLH market minimum

Light-load-hour market previously ranged from 999 MW to 200 MW depending on load (higher load correlated with lower market). New market ranges from 999 MW to 400 MW. This **reduces need in both seasons.**

	(MW)							
	Summer	Winter						
July 2022 draft need results	761	863						
Switch to 30 temp years	62 ↑	(34)↓						
Switch to 30 hydro years	13 ↑	(3)↓						
Increase to 400 LLH market	(7)↓	(23)↓						

Impacts shown are individual and marginal, not cumulative



Cumulative results

Summer need increases by 67 MW, winter need falls by 56 MW.

	Year 2026 cap (MV	acity impact V)
	Summer	Winter
July 2022 draft need results	761	863
Switch to 30 temp years	62 ↑	(34)↓
Switch to 30 hydro years	13 ↑	(3)↓
Increase to 400 LLH market	(7)↓	(23)↓
Oct. 2022 draft need results	828 ↑	807↓

Individual marginal changes will not necessarily sum to the total change



Updated reference case capacity need



-IRP Roundtable 10/26/2022 57

FLEXIBILITY ANALYSIS

ANA MILEVA, BLUE MARBLE ANALYTICS ROUNDTABLE 22-9





Blue Marble Analytics creates innovative, high-quality grid analytics software to guide clean energy planning and policy.

We provide consulting and software-development services for power-system planning and portfolio optimization and management.





Ana Mileva is the founder of Blue Marble Analytics and the primary architect of the GridPath platform. She was previously a consultant at E3. And has wide-ranging experience consulting and developing planning models for utilities, government agencies, NGOs, and developers.

Analvtics

Experience in the last two PGE IRPs

- 2016 IRP: led capacity-adequacy and reliability study (E3)
- 2019 IRP: led flexibility adequacy analysis ٠

Expertise across a range of topics including:

- Software development
- Data analytics
- Resource planning and portfolio optimization
- Asset optimization and valuation
- **Renewables** integration
- Storage, demand response, hybrid resources
- Clean energy policy

All data is draft until filed.



Flexibility Analysis Scope Overview

- A set of studies that aim to assess **flexibility needs, costs, and value**.
- Studies will be conducted using multi-stage optimal commitment and dispatch in GridPath, an open-source grid planning platform.





GridPath is an open-source modeling ecosystem that enables faster and more technically sophisticated planning for the clean energy transition.



Debe Other Debe	+- 🍘			
Profession Observe Observe Addition Addition Instruction Instruction Instruction Instruction Instruction Instruction Instruction Instruction Instruction Instruction <th>44 -</th>	44 -			
analysis Morego eff regard 1285 from the evertablemetry in x transit on the S () 1386 cmth a charter bandwords to 10850000 a charter bandwords to 108500000 a charter bandwords to 108500000000000000000000000000000000000	8			
a photowarkhow	mization Inning and			
Beinstein State				
det Update dus image hils (#55) a multi sgi annole Loos oh for #55 a multi sgi annole Loos of				
Biosophie Discussion fields 3 andré spij Sender Stranger (response di Appel file name (EERS) 3 modit kaji Sender Stranger (response di Appel file name (EERS) 3 modit kaji Sender Stranger (response di Appel file name (EERS) 3 modit kaji Sender Stranger (response di Appel file name (EERS) 3 modit kaji Sender Stranger (response di Appel file name (EERS) 3 modit kaji Sender Stranger (response di Appel file name (EERS) 3 modit kaji Sender Stranger (response di Appel file name (EESS) 2 pares di Appel file name (EESS)	9			
	renewable-energy renewables			
Book Seport for for latituding (HSS) A starting and the sector build of the sector build				
def Constant Con				
	D Readme			
Dipony Additionality (Dipony (RSR) 2 years and 2 years and 2 working to be uncertained. 2 years and 2 years and 2 years and 2 working to be uncertained. 2 years and 2 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained. 0 working to be uncertained.				
LUCINSE-rd Central LCINEE-red (PT/1) 2 years app Y 2 lots MUNETSIN Add MMOETSIN (red (PT/2)) 2 years app Releases itil D MUNETSIN Add MMOETSIN (red (PT/2)) 3 years app Releases itil D MARATERIN LOUT Compared numps to v1215 3 moths app motion set D Method my Dompared numps to v1215 3 moths app • trebases D Method my Dompared numps to v1215 3 moths app • trebases D Method my Dompared numps to v1215 3 moths app • trebases E RADAELend Compared numps to v1215 3 moths app • trebases				
D. MARTESE Add MARTESE In (r/m27) 2 years applied B. KALAK Update locs in logic loci (KEB) 3 months applied D. wearsamentation. Domograde montp to 1218 3 months applied D. wearsamp Domograde montp to 1218 3 months applied Wearsamp Bung wearsamentation to 121 3 months applied B. KABAK_EM Bung wearsamentation to 121 3 months applied B. KABAK_EM Bung wearsamentation to 121 3 months applied B. KABAK_EM Bung wearsamentation to 121 3 months applied				
BOARER Update docs image Nas (MSD) 3 months age Releases 10 Maximum Statu Dewaysing many tor V125 3 months age Image Nas (MSD) Make proj Demagrade many tor V125 3 months age Image Nas (MSD) J weiken proj Demagrade many tor V125 3 months age J Make proj Demagrade many tor V125 3 months age J Make proj Demagrade many tor V125 3 months age J Maximum Strateging Age Professor				
D revenenced bot Domegrade numpy to 1215 3 munits ago Domegrade numpy to 1215 3 munit				
Description Descripti Descripti Description Description Description				
Version py Bump version to vici2 Journal of the vici2 RELOWErnd Recommendation Recommendation Recommendation Recommendation Recommendation Recommendation Recommendation				
README.ind Process				
Dited with passes dos passes provide the policy of the pol				
The second s				
Welcome to GridBath Contributors 2				

- Open-source codebase available at <u>https://github.com/blue-marble/gridpath</u>
- GridPath has been benchmarked against
 PLEXOS and RESOLVE



Flexibility Modeling of PGE's System with GridPath

Multi-stage unit-commitment and dispatch



Generators modeled with a high level of operational fidelity

Heat rate Minimum up curves and down times Ramp rates Includes market availability, regulation, contingency, and loadfollowing reserve requirements

Blue Marble Analytics All data is draft until filed.

GridPath Base Case Set-up

GridPath Base Case Set-up

Input	Flexibility Adequacy Study	Flexibility Value and Integration Cost Studies
Time frame	2026	2026
Gas prices	Reference	Reference
Carbon prices	Reference	Reference
Electricity prices	Reference	Reference
Load	Updated to 2026, average year	Updated to 2026, average year
VER generation	Updated to 2026, average year	Updated to 2026, average year
Existing contracts	Updated	Updated
Market availability	Limited in on-peak summer and winter Unconstrained in off-peak and non-winter and summer peak	Limited in on-peak summer and winter Unconstrained in off-peak and non-winter and summer peak
Reserves	Regulation, contingency, and load-following reserves	Regulation, contingency, and load-following reserves
Capacity Availability	DA, HLH block capacity that is more expensive than existing system generation & markets	RFP proxy resources including new wind, solar, and batteries & expensive, unconstrained purchases



Flexibility Adequacy



Measuring Unserved Energy Due to Flexibility (USE_{Flex})

- Important to distinguish between loss-of-load events attributable to flexibility shortages and those due to capacity shortages
- The approach also distinguishes between uncertainty- and variabilityrelated events



Blue Marble Analytics

Unserved Energy Due to Flexibility

Real Time Unserved Energy (USE)								
# Timepoints	36							
% Timepoints	0.1%							
Total MWh	158							
Max MW	80							



- All realized USE occurs during times when the DA capacity is not fully committed
 - USE is caused by insufficient flexibility, not capacity shortages
- Ramping constraints don't bind during the times with USE
 - Flexibility events are caused by forecast error, not insufficient ramping capability

All data is draft until filed.



Seasonal Distribution of USE_{Flex}

HOUR ENDING

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Jan																			0.6					
Feb							0.0	0.5								0.0	0.4		0.8					
Mar																								
Apr																								
May																								
Jun																								
Jul																					0.4			
Aug																					0.0	0.5		
Sep																			0.0	0.8				
Oct																								
Nov																								
Dec												0.0	0.6											
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Jan																		0.0%	3.2%	1.6%		0.0%	1.6%	
Feb							0.9%	2.7%											3.6%					
Mar																			0.0%					
Apr																								
May																								
Jun																								
Jul																				0.8%	1.6%			
Aug																				0.0%	0.0%	3.2%		
Sep																			0.0%	1.7%	0.8%	0.0%		
Oct																			0.0%	0.0%				
Nov																								
Dec																								



 In planning scenarios, flexibility-related unserved energy is concentrated during the winter and summer evening net load peak hours

All data is draft until filed.

MWa USE

% TIME WITH USE



Estimated Flexibility Headroom



Blue Marble

Analytics

- From a long-term planning perspective, PGE's system is most headroomconstrained in the winter months
- Headroom during the summer months is higher on average but also drops to ~250 MW or below around 10% of the time
- Headroom is more plentiful in the spring



All data is draft until filed.

Flexibility Adequacy Key Takeaways

- If no flexible resources are added and the resource adequacy need is filled with an inflexible block DA product, flexibility challenges are encountered by the model
- In this planning scenario, the key driver of flexibility challenges for the system is forecast error, not operational constraints such as ramping or minimum up/down time
- The times of flexibility need are aligned with times of resource adequacy stress
- The flexibility adequacy issues encountered could be addressed by planning for a diverse portfolio containing wind and solar, and operationally flexible hybrid resources and batteries instead of highly inflexible DA capacity blocks



Flexibility Value



Flexibility Value

- Objective: estimate operational flexibility value of different new resources when added to the PGE system in 2026
- A case is run with and without each potential new resource, and system operational costs are compared

	Round-trip Efficiency
2-hour Battery	
4-hour Battery	QE0/
6-hour Battery	0570
8-hour Battery	
10-hour PHS	80%



All data is draft until filed.
Flexibility Value



	Flexibility Value (2023\$/kW-year)
2-hour Battery	8.35
4-hour Battery	9.77
6-hour Battery	10.68
8-hour Battery	11.78
10-hour PHS	11.47

- Values are dependent on the system the resources are added to, e.g., VER penetration, other flexibility resources, market assumptions, etc.
- Marginal flexibility benefits decrease as more flexible resource capacity is added to the system
- These numbers represent "mid" estimates



Integration Costs



VER Integration Costs

 Objective: estimate integration costs of different new resources when added to the PGE system in 2026

	Solar	MT wind	WA wind
Integration Cost (2023\$/MWh)	2.83	0.95	2.57

- Test resources: MT wind, WA wind, solar
- 100 aMW of each new resource is added to the system in separate runs
- Incremental cost of the test resource estimated as the difference in system cost relative to a separate case adding 100 aMW resource block matching weekly capacity factor to isolate operational costs over short timeframes



Thank You

Contact ana@bluemarble.run

PORTFOLIO ANALYSIS

NIHIT SHAH, Principal Integrated Resource Planning Analyst ROUNDTABLE 22-9



Portfolio analysis in the 2023 IRP

June Roundtable review

In the coming IRP, portfolio analysis will be conducted like earlier iterations:

- Model will choose optimal combination of proxy supply-side resources
- Cost, risk metrics, and portfolio-CBIs be used to determine a Preferred Portfolio and Action Plan

Given the uncertainty of the resources required to meet 2040's emission reduction targets, portfolio analysis post 2030 will focus on:

- System requirements (more granularity on energy and capacity needs)
- A qualitative assessment of the possible pathways to 2040

This will provide to us (both PGE and our public participants) the opportunity to evaluate viable emission-free options that traditional analysis with current supply-side options would not provide

IRP Roundtable 6/30/2022

Portfolio analysis - Definitions

Portfolio: A fixed set of resource decisions set in all scenarios. The model (ROSE-E) creates resource buildouts around those choices in each scenario.

Scenarios: Refer to elements that are varied within portfolio analysis resulting in multiple resource buildouts. Some of the predefined scenarios are - need, technology cost, price, hydro.

Resource buildout: Least cost set of incremental resource additions given a set of specific input conditions such as a portfolio and scenario.

Sensitivities: Sensitivities test the robustness or provide additional information on the preferred portfolio by forcing changes resource constraints or other inputs.

IRP Roundtable 10/26/2022

From a portfolio to the Preferred Portfolio

Portfolio scoring currently under development



Portfolios ideas

Portfolio ideas	Description
Hydrogen, offshore wind, long duration storage	A portfolio that includes each of these technologies per UM2225
Pumped hydro storage (PSH)	Limiting the build of PSH to one project
Oregon-only resources	Limiting selection to only Oregon-sited resources

IRP Roundtable 10/26/2022

Additional portfolio options

Community based renewable energy resources

Transmission expansion

Non-cost-effective energy efficiency (EE) and demand response (DR)

Stakeholder's portfolio ideas \rightarrow <u>IRP@PGN.com</u> by 11/4/2022

CLEAN ENERGY PLAN UPDATE

ANGELA LONG, Senior Manager Strategy & Planning Distributed Resource Planning ROUNDTABLE 22-9

NEXT STEPS

A recording from today's webinar will be available in one week

Upcoming Roundtables:

- November 16
- December 15
- January 26
- February 23
- March TBD

IRP Roundtable 10/26/2022 83



THANK YOU

CONTACT US AT: IRP@PGN.COM

APPENDIX A: CLIMATE STUDY





APPENDIX





Academia Review





Academia Review of Climate Change Impacts

Entity	Title	Region	Load 8	Gen Climate Risks	in IRP	Notes:
<u>Compound climate events transform</u>	D.111/	Electric Demand	Solar Gen	Thermal Gen	Electric demand and hydro generation adjusted for two climate. GENSYS used to estimate resource adequacy	
Pacific Northwest	acific Northwest NATIONAL LABORATORY	PNW	Hydro Gen	Wind Gen	Storage	of PNW. Regional LOLP doubled, but peak capacity need reduced by 60%.
\wedge	Analysis of Drought Impacts on Electricity Production in the Western	Western US and TX	Electric Demand	Solar Gen	Thermal Gen	Historically, 10-year drought reduces hydroelectric generation by 26% in the PNW.
Argonne	and Texas Interconnections of the United States.		Hydro Gen	Wind Gen	Storage	
Centro UC Cambio Global	Climate change impacts on two high-		Electric Demand	Solar Gen	Thermal Gen	Rising temperature will reduce annual hydropower
O Berkeley	<u>elevation nydropower systems in</u> <u>California</u> .	CA	Hydro Gen	Wind Gen	Storage	generation by up to 8.2% in 2050 in CA.
A Portland State	Portland State	or wind	Electric Demand	Solar Gen	Thermal Gen	Wind generation potential may reduce by 40% in spring
power resources in the Northwest United States	PNW	Hydro Gen	Wind Gen	Storage	and summer months due to a 4-6% decrease in wind speed in Northwest U.S.	
TH zürich	ETHZÜRICH Projections of long-term changes in solar radiation based on CMIP5 climate models and their influence on energy yields of photovoltaic systems	ong-term changes in n based on CMIP5 PNW, CA,	Electric Demand	Solar Gen	Thermal Gen	Rising solar radiation (GHI) is likely to increase solar
		Climate models and their influence on energy yields of photovoltaic systems	U.S.	Hydro Gen	Wind Gen	Storage
ARIZONA BOARD OF REGENTS ASU + NAU + UA	Impacts of climate change on electric	Western US	Electric Demand	Solar Gen	Thermal Gen	Climate change driven temperature changes in the
Arizona State University	western 05	Hydro Gen	Wind Gen	Storage	capacity of thermal facilities by 1.4-3.5%.	
Pacific Northwest NATIONAL LABORATORY	<u>Climate Change Impacts on</u> Residential and Commercial Loads in		Electric Demand	Solar Gen	Thermal Gen	Commercial buildings will see 5-10% increase in their peak load (MW), while residential buildings will see more than 10% increase in peak load by 2045 in Western U.S. Both sectors will see a 2.8% increase in morthly.
	the Western U.S. Grid	western US	Hydro Gen	Wind Gen	Storage	summer load (MWh), due to increased AC usage. Autumn and Spring monthly load experience similar increase too.



Climate Modeling Data Conversion Process



Climate Modeling – Emission Scenarios



- Produced by the Intergovernmental Panel of Climate Change (IPCC) in 2014, Representative Concertation Pathways (RCP) are standardized future scenarios of atmospheric greenhouse gas concentrations and corresponding radiative forcing.
 - Four pathways were developed describing potential global warming temperature rise by 2100, spanning a broad range of radiative forcing (2.6, 4.5, 6.0, and 8.5 watts per meter squared)
 - Only RCP1.9 limits global warming to below 1.5 °C, the goal of the 2015 Paris Agreement.
- Introduced in 2020 by the IPCC, Shared Social Economic Pathways (SSPs) are five pathways describing broad socioeconomic trends that could shape future society and ultimately lead to certain RCP pathways.
 - "Narrative" behind the RCP pathways.
 - Only SSP5 produces a reference scenario that is consistent with RCP8.5.



Climate Modeling – GCMs Models



- A global climate model (GCM) is a complex mathematical representation of the major climate system components (atmosphere, land surface, ocean, and sea ice), and their interactions. Earth's energy balance between the four components is the key to long-term climate prediction.
- Climate models are constantly being updated, as different modelling groups around the world incorporate higher spatial resolution, new physical processes and biogeochemical cycles.
- The 2021 IPCC sixth assessment report (AR6) features new state-of-the-art CMIP6 models. CMIP6 will consist of the "runs" from around 100 distinct climate models being produced across 49 different modelling groups



Climate Modeling – Downscaling



- Downscaling methods are used to refine the temporal and spatial resolution of GCM weather predictions, capturing the more granular effect of geography and other factors that are missed by coarse GCM models.
- There are two general approaches of downscaling:
 - Dynamical Outputs from a GCM are used to drive higher resolution regional climate models (RCM) with a better representation of local terrain and other conditions.
 - Statistical where statistical links are established between large-scale climate phenomena and observed local-scale climate. (Bias correction required).



Climate Modeling – Weather Research & Forecasting



- Weather Research & Forecasting Models are mesoscale numerical weather prediction model used to further dynamically downscale climate data to a higher resolution over regions of interest.
- WRF models can be adapted and utilized as RCM models for the purpose of downscaling data. However, several technical differences exist, and WRF models are better for localized weather event predictions.
- WRFs are useful at predicting weather at temporal and spatial resolutions for energy modeling.





Quantifying Climate Change Impact for Load & Generation



Climate Change Impacts on Utility Planning - I



© 2022 Creative Renewable Solutions, LLC.

 PUBLIC
 Note: Resiliency not a part of resource adequacy discussion above, which pertains to speed of recovery.
 95



Load Forecasting - I



- While weather is a highly influential factor in load forecasting process, the impact will vary on different segments of demand side modeling.
 - **<u>Residential Load:</u>** Residential customers see greater energy usage as AC uptake increases with warming temperatures.
 - <u>Commercial/Industrial Load:</u> Industrial customers are less temperature dependent and may be influenced more by economic metrics.
 - <u>Peak Load</u>: Higher daily max temperatures in the summer and higher minimum temperatures in the winter will shift load peaking seasons.
 - <u>BTM Solar:</u> BTM solar generation panels efficiency degrades in warmer temperatures, offset by greater solar radiance.
 - <u>Transport/DR/EE</u>: Likely less influenced by climate factors in adoption and costbenefit models.



Long-Term Load Forecasting - II

Several load modeling frameworks (Statistical, ML, hybrid) exist, but further investigation is required to identify the most "accurate" methodologies. ML techniques such as LSTM have shown promising results in prior research.





Hydro Forecasting - I



÷	ト	Creative		
~~~	<u>'</u>	Renewable		
•	Solutions			

#### Hydro Forecasting - II



© 2022 Creative Renewable Solutions, LLC.

PUBLIC

[1] Figures from Koch, Julian (2016). Evaluating spatial patterns in hydrological modelling. 10.131a/JR6.2.2.34737 79204. [2] Figure from Mizukami, Naoki & Clark, Martyn & Gutmann, Ethan & Mendoza, Pablo & Newman, A. & Nijssen, Bart & Lineh, Ben & Har, Juaren & Annold, Jeffrey. (2016). Implications of the methodological choices for hydrologic portrayals of climate change over the Contiguous United. Journal of hydrometorology. 17. 10.1175/HM-D-14-0187.1. [3] Table from Histry/clioiorg/10.2194/plains.383-261-2020



#### Hydro Forecasting - III





#### Hydro Forecasting - IV





#### Wind Forecasting - I





#### Wind Forecasting - II



#### The polar coordinates V and $\phi$ are calculated from the cartesian V_N and V_F by Equations (1) and (2) below.



where V1 and V2 are the wind speeds at heights  $H_1$  and  $H_2$ , and where  $H_0$  is the roughness coefficient length, in meters.





#### Wind Forecasting - III





#### Solar Forecasting - I





#### Solar Forecasting - II





#### **Thermal Generation Forecasting**



- Climate change impacts thermal powered generators by reducing the availability of thermal units (i.e., higher forced outages) and decreasing the capacity of available thermal units.
- Historically, thermal units have been derated based on seasonal capacity ratings (summer/winter) and the availability described by an annual forced outage rate (uncorrelated availability).
- However, multiple studies using NERC GAD data has shown a correlation between temperature and the availability of capacity from thermal units.
- <u>Thermal Derating & Forced Outage</u> <u>Modeling:</u> Modeling used to represent the number of available thermal units and their respective capacities incorporating the dynamic impact of temperature.



#### **Thermal Generation Forecasting**



PUBLIC

https://doi.org/10.1016/i.applthermaleng.2011.04.045.
 https://doi.org/10.1016/i.joei.2014.07.006
 https://doi.org/10.1016/i.apenergy.2019.114424


## **Climate Change Impacts on Utility Planning Recap**



© 2022 Creative Renewable Solutions, LLC.

PUBLIC

Note: All impacts are illustrative only. Does not include other potential risks (flooding, storms, etc.) Climate change impact could also reduce peak need in certain scenarios and seasons.