



## ICC-ES Listing Report ESL-1002

Reissued June 2024

This listing report is subject to renewal June 2025.

**CSI:** DIVISION: 06 00 00—WOOD, PLASTICS AND COMPOSITES  
Section: 06 05 83—Shop-applied Wood Coatings  
Section: 06 16 00—Sheathing

### Product Certification System:

The ICC-ES product certification system includes evaluating reports of tests of standard manufactured product, prepared by accredited testing laboratories and provided by the listee, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the listee's quality system.

**Products:** LP® FLAMEBLOCK® FIRE-RATED SHEATHING

**Listee:** LOUISIANA-PACIFIC CORPORATION

**Evaluation:** LP® FlameBlock® Fire-Rated Sheathing (includes the former Blazeguard® Fire-Rated Sheathing), were evaluated when tested in accordance with the following standards:

- ASTM E84 (-18B, -16, -13A, -09), Standard Test Methods for Surface Burning Characteristics of Building Materials, ASTM International.
- UL 723 (-18, -08), Standard for Test for Surface Burning Characteristics of Building Materials, Underwriters Laboratories, Inc.

**Findings:** LP® FlameBlock® Fire-Rated Sheathing (includes the former Blazeguard® Fire-Rated Sheathing) have a flame-spread index of 25 or less and a smoke-developed index of 450 or less, based on testing in accordance with ASTM E84/UL723, as referenced in the applicable sections of the following code editions:

- 2021, 2018, 2015 and 2012 *International Building Code*® (IBC)  
Applicable Section: 803.1
- 2021, 2018, 2015 and 2012 *International Residential Code*® (IRC)  
Applicable Section: R302.9

### Identification:

1. Each panel of LP® FlameBlock® Fire-Rated Sheathing (includes the former Blazeguard® Fire-Rated Sheathing), is identified with a label indicating the listee's name (Louisiana-Pacific Corporation), the product name, the product identification number, the listing report number (ESL-1002), and/or the evaluation report number ([ESR-1365](#)), and when applicable, the listing mark.
2. The report holder's contact information is the following:

**LOUISIANA-PACIFIC CORPORATION**  
**1610 WEST END AVENUE, SUITE 200**  
**NASHVILLE, TENNESSEE 37203**  
**(880) 820-3025**  
[www.lpcorp.com](http://www.lpcorp.com)

**Installation:** The products must be installed in accordance with the Louisiana-Pacific Corporation's installation instructions.

**Conditions of listing:**

1. This listing report addresses only those findings noted above. Additional attributes and their applications can be found in the ICC-ES Evaluation Report, [ESR-1365](#).
2. For surface burning characteristics reported for walls and ceilings, the panels must be installed with the fire exposure on the Pyrotite laminate side.
3. Approval is the sole responsibility of the local code official.
4. This listing report applies only to the materials tested and as submitted for review by ICC-ES.