

DIVISION: 06 00 00—WOOD, PLASTICS AND COMPOSITES
Section: 06 16 00—Sheathing

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION
Section: 07 46 23—Wood Siding

REPORT HOLDER:

LOUISIANA-PACIFIC CORPORATION

EVALUATION SUBJECT:

LP® SMARTSIDE® STRAND SUBSTRATE LAP SIDING AND LP® SMARTSIDE® STRAND SUBSTRATE PANEL SIDING

1.0 REPORT PURPOSE AND SCOPE**Purpose:**

The purpose of this evaluation report supplement is to indicate that LP® SmartSide® Strand Substrate Lap Siding and LP® SmartSide® Strand Substrate Panel Siding, described in ICC-ES evaluation report [ESR-1301](#), have also been evaluated for compliance with the codes noted below as adopted by the Los Angeles Department of Building and Safety (LADBS).

Applicable code editions:

- 2020 *City of Los Angeles Building Code* (LABC)
- 2020 *City of Los Angeles Residential Code* (LARC)

2.0 CONCLUSIONS

The LP® SmartSide® Strand Substrate Lap Siding and LP® SmartSide® Strand Substrate Panel Siding, described in Sections 2.0 through 7.0 of the evaluation report [ESR-1301](#), comply with the LABC Chapters 14 and 23, and the LARC, and are subject to the conditions of use described in this supplement.

3.0 CONDITIONS OF USE

The LP® SmartSide® Strand Substrate Lap Siding and LP® SmartSide® Strand Substrate Panel Siding described in this evaluation report supplement must comply with all of the following conditions:

- All applicable sections in the evaluation report [ESR-1301](#).
- The design, installation, conditions of use and identification are in accordance with the 2018 *International Building Code*® (IBC) and 2018 *International Residential Code* (IRC) provisions noted in the evaluation report [ESR-1301](#).
- The design, installation and inspection are in accordance with additional requirements of LABC Chapters 16 and 17, as applicable.
- Panels must be used only in locations where combustible materials are permitted in the 2020 LABC.
- Under the LARC, an engineered design in accordance with LARC Section R301.1.3 must be submitted.
- The LP® SmartSide® Strand Substrate Lap Siding and LP® SmartSide® Strand Substrate Panel Siding have not been evaluated under the LABC Chapter 7A or the LARC Section R337 for use in the exterior design and construction of new buildings located in any Fire Hazard Severity Zone within State Responsibility Areas of any Wildland – Urban Interface Area.

This supplement expires concurrently with the evaluation report, reissued March 2022.