



LP WeatherLogic[®] Air & Water Barrier
Louisiana-Pacific Corporation

PR-N138
Revised February 19, 2025

Products: LP WeatherLogic[®] Air & Water Barrier

LP Building Solutions, Louisiana-Pacific Corporation, 1610 West End Ave., Nashville, TN 37203
(888) 820-0325

www.lpcorp.com

1. Basis of the product report:

- 2021, 2018 International Building Code (IBC): Sections 104.11 Alternative materials, 1403.2 Water-resistive barrier, 1505 Fire Classification, and 1507 Requirements for Roof Coverings
- 2015, and 2012 IBC: Sections 104.11 Alternative materials and 1404.2 Water-resistive barrier, 1505 Fire Classification, and 1507 Requirements for Roof Coverings
- 2021, 2018, 2015, and 2012 International Residential Code (IRC): Sections R104.11 Alternative materials, R703.2 Water-resistive barrier, R902 Fire Classification (Roof Classification for 2012 IRC), and R905 Requirements for Roof Coverings
- 2021, 2018, and 2015 International Energy Conservation Code (IECC): Sections C102 Alternative materials, R102 Alternative materials, C402.5.1 Air barriers, and R402.4 Air leakage
- 2012 IECC: Sections C102 Alternative materials, R102 Alternative materials, C402.4.1 Air barriers, and R402.4 Air leakage
- 2021 Oregon Residential Specialty Code
- DOC PS 2-18, Performance Standard for Wood Structural Panels
- APA Panel Design Specification
- Qualification reports and other qualification data

2. Product description:

LP WeatherLogic[®] Air & Water Barrier is a system of wood structural panels, with panel joints sealed with approved tape or liquid-applied sealant, used to construct roofs and exterior walls with integrated sheathing and water-resistive barrier. When used to construct exterior walls, the system also serves as an air barrier.

LP WeatherLogic Air & Water Barrier panels consist of Louisiana-Pacific 7/16 through 5/8 Performance Category oriented strand board (OSB) Exposure 1 Structural I Rated Sheathing complying with DOC PS 2 and manufactured in accordance with the in-plant manufacturing standard approved by APA and adhered with a factory-applied proprietary overlay.

LP WeatherLogic Seam & Flashing Tape is a pressure sensitive, coated polymeric film that is minimum 3-3/4 inches in width. The tape is used for sealing panel joints, penetrations, openings, and material transitions. The tape has been tested in accordance with Method F of ASTM D3330, *Standard Test Method for Peel Adhesion of Pressure-Sensitive Tape*, and meets or exceeds the requirements specified in AAMA 711-20, *Specification for Self-Adhering Flashing Used for Installation of Exterior Wall Fenestration Products*, for Type A, Class Level 3.

LP WeatherLogic Seam & Flashing Sealant is a liquid-applied sealant used for sealing panel joints, penetrations, openings, and material transitions. The sealant has been tested in accordance with ASTM C794, *Standard Test Method for Adhesion-in-Peel of Elastomeric Joint Sealants*, and meets or exceeds the requirements specified in AAMA 714-19, *Specification for Liquid-Applied Flashing Used to Create a Water-Resistive Seal Around Exterior Wall Openings in Buildings*, for Level 3, Category I.

LP WeatherLogic Air & Water Barrier has been evaluated for compliance with the IBC and IRC for use as a combination of wall sheathing, water-resistive barrier, and air barrier, and a combination of roof sheathing and roof underlayment. LP WeatherLogic Air & Water Barrier has also been evaluated in accordance with ASTM E2357, *Standard Test Method for Determining Air Leakage Rate of Air Barrier Assemblies*, and ASTM E2273, *Standard Test Method for Determining the Drainage Efficiency of Exterior Insulation and Finish Systems (EIFS) Clad Wall Assemblies*. LP WeatherLogic Air & Water Barrier exceeds the 75% drainage efficiency requirement specified in Exception 1 to Section R703.1.1 of the Oregon Residential Specialty Code.

When installed with LP WeatherLogic Seam & Flashing Tape or LP WeatherLogic Seam & Flashing Sealant described in this section in accordance with the installation requirements specified in Section 4 of this report, LP WeatherLogic Air & Water Barrier shall be permitted for use in:

- a) Walls of Type V construction in the IBC and one- and two-family dwellings in the IRC, and as an alternative to the water-resistive barrier required in Chapters 14 of the IBC and Chapter 7 of the IRC.
- b) Roofs with a pitch of 2:12 or greater for Type III and Type V construction in the IBC and one- and two-family dwellings in the IRC as a combination roof sheathing and roof underlayment with the following limitations:
 - 1) For installations under the IBC, Type III-A and Type V-A shall be in accordance with IBC Table 601 footnotes b and d.
 - 2) An ice barrier shall be provided in accordance with Section 1507.1.2 of the 2021 and 2018 IBC, 1507 of the 2015 and 2012 IBC, or R905 of the 2021, 2018, 2015, and 2012 IRC.
 - 3) Enclosed attic and rafter spaces shall be ventilated in accordance with applicable code except where unvented assemblies are permitted by Section R806.5 of the 2021, 2018, 2015, and 2012 IRC.

The manufacturing processes and quality assurance of the LP WeatherLogic Air & Water Barrier panels, Seam & Flashing Tape and Seam & Flashing Sealant are documented in the in-plant manufacturing standard approved by APA.

3. Panel performance properties:

LP WeatherLogic Air & Water Barrier panels meet the design properties specified in APA *Panel Design Specification*, Form D510 (www.apawood.org/resource-library) for Exposure 1 Structural I panels with a span rating of 24/16, 32/16, or 40/20 as designated on the panel trademark.

LP WeatherLogic Air & Water Barrier panels shall be designed for wind uplift at a design span not exceeding the span rating shown in the trademark in accordance with Sections 1609 of the IBC, 2304.8.2 of the 2021, 2018, and 2015 IBC or 2304.7.2 of the 2012 IBC, and R301.2.1 of the IRC. Roof coverings shall be mechanically fastened to the panels to resist the design wind uplift.

LP WeatherLogic Air & Water Barrier has been tested in accordance with ASTM E96, *Standard Test Methods for Water Vapor Transmission of Materials*, and has the following characteristics:

- a) Vapor permeance of 1.27 perms and equivalent Water Vapor Transmission (WVT) rate of 8.84 g/(24h-m²) when tested in accordance with ASTM E96 (desiccant method) at 73.4 ± 1°F and 50 ± 2% relative humidity.
- b) Vapor permeance of 5.35 perms and equivalent WVT rate of 36.1 g/(24h-m²) when tested in accordance with ASTM E96 (water method) at 73.4 ± 1°F and 50 ± 2% relative humidity.

When manufactured in compliance with facing materials for structural insulated panels (SIPs) in accordance with Table 2 of ANSI/APA PRS 610.1 referenced in Section R610.3 of the 2021 and 2018 IRC, Section R610.3.2 and Table R610.3.2 of the 2015 IRC, and Section R613.3.2 and Table R613.3.2 of the 2012 IRC, the water-resistive barrier properties of the LP WeatherLogic Air & Water Barrier are not affected by the manufacturing processes.

4. Product installation:
LP WeatherLogic Air & Water Barrier recognized in this report shall be installed in accordance with recommendations provided by the manufacturer (<https://lpcorp.com/resources/product-literature/installation-instructions/lp-weatherlogic>).
5. Fire-resistant construction:
 - a) LP WeatherLogic Air & Water Barrier meets Class III (or C) flame spread index and smoke-developed index when tested in accordance with ASTM E84, *Standard Test Method for Surface Burning Characteristics of Building Materials*.
 - b) LP WeatherLogic Air & Water Barrier meets a Class B fire classification as the underlayment for roof assemblies covered with ASTM D3018, *Standard Specification for Class A Asphalt Shingles Surfaced with Mineral Granules*, Class A asphalt fiberglass shingles when tested in accordance with ASTM E108, *Standard Test Methods for Fire Tests of Roof Coverings*.
Exception: LP WeatherLogic Air & Water Barrier with a Performance Category of 15/32 or greater meets a Class A fire classification as the underlayment for roof assemblies covered with ASTM D3018 Class A asphalt fiberglass shingles.
 - c) LP WeatherLogic Air & Water Barrier is permitted to be used with nonclassified roof coverings in accordance with Table 1505.1 footnote b and Section 1505.5 of the IBC, and Section R902.1 of the IRC.
6. Limitations:
 - a) LP WeatherLogic Air & Water Barrier recognized in this report shall be used in a design span not exceeding the span rating shown in the trademark.
 - b) LP WeatherLogic Air & Water Barrier is limited to dry service conditions where the average equilibrium moisture content of sawn lumber is less than 16%.
 - c) When used as roof assemblies and coverings, LP WeatherLogic Air & Water Barrier is limited to a slope of not less than 2 units vertical in 12 units horizontal (17% slope).
 - d) LP WeatherLogic Air & Water Barrier meets a Class B fire classification as the underlayment for roof assemblies covered with ASTM D3018 Class A asphalt fiberglass shingles except that LP WeatherLogic Air & Water Barrier with a Performance Category of 15/32 or greater meets a Class A fire classification.
 - e) LP WeatherLogic Air & Water Barrier is produced by LP at the Clarke County manufacturing facility in Thomasville, AL under a quality assurance program audited by APA.
 - f) This report is subject to re-examination in one year.
7. Identification:
LP WeatherLogic Air & Water Barrier described in this report is identified by a label or stamp bearing the manufacturer's name and/or trademark (Louisiana-Pacific Corporation), the APA assigned plant number (520 for the Clarke County plant), the product thickness and span rating, the APA logo, the report number PR-N138, and a means of identifying the date of manufacture.



Figure 1. Typical LP WeatherLogic Air & Water Barrier Mark

APA – *The Engineered Wood Association* is an approved national standards developer accredited by American National Standards Institute (ANSI). APA publishes ANSI standards and Voluntary Product Standards for wood structural panels and engineered wood products. APA is an accredited certification body under ISO/IEC 17065 by Standards Council of Canada (SCC), an accredited inspection agency under ISO/IEC 17020 by ANSI National Accreditation Board (ANAB), and an accredited testing organization under ISO/IEC 17025 by ANAB. APA is also an approved Product Certification Agency, Testing Laboratory, Quality Assurance Entity, Validation Entity, and Product Evaluation Entity by the State of Florida, and an approved testing laboratory by City of Los Angeles.

**APA – THE ENGINEERED WOOD ASSOCIATION
HEADQUARTERS**

7011 So. 19th St. • Tacoma, Washington 98466
Phone: (253) 565-6600 • Fax: (253) 565-7265 • Internet Address: www.apawood.org

PRODUCT SUPPORT HELP DESK
(253) 620-7400 • E-mail Address: help@apawood.org

DISCLAIMER

APA Product Report® is a trademark of APA – *The Engineered Wood Association*, Tacoma, Washington. The information contained herein is based on the product evaluation in accordance with the references noted in this report. No warranties, express or implied, including as to fitness for a particular purpose, are made regarding this report. Neither APA nor its members shall be liable, or assume any legal liability or responsibility, for damages, direct or indirect, arising from the use, application of, and/or reference to opinions, findings, conclusions or recommendations included in this report. Consult your local jurisdiction or design professional to assure compliance with code, construction, and performance requirements. Because APA has no control over quality of workmanship or the conditions under which engineered wood products are used, it cannot accept responsibility for product performance or designs as actually constructed.