

Installation guide

Easee Base



Table of contents

Introduction	4
Technical specifications	Ę
Safety instructions	6
Common parts	8
Adapter plate	Ġ
1-Way	10
2-Way]4
3-Way / 4-Way	18
Power Rail	26
Before connecting	27
Ground connection plate	28
Terminals	3
Wiring	33
Side panel	36
Practical details	37

Introduction

Easee Base

The Easee Base is a modular charging post for mounting up to four Easee Charging Robots.

With Easee Base, it is possible to choose between four different configurations. One-way setup where only one charger is mounted, 2-way setup with two chargers, 3-way setup with three chargers and finally 4-way setup where there is a charger on all sides of the post.

With four configurations in one design, they share many common parts. Only a few parts are specific to each type of layout.

Conventions



This symbol indicates that the respective instructions must only be carried out by an authorised electrician.



This symbol indicates an immediate danger to life and health of persons due to the effects of electrical energy. Non-observance of these instructions will result in serious damage to health - up to and including life-threatening injuries.

Technical specifications

General Dimension (mm): H: 1500 x W: 156 x D: 80

Weight: 6.1-7.7 kg Material: Aluminium Finish: Powder coating

Colour: Black IP degree: IP44

Features Adapter plate for c/c 160 mm² foundation

45 degree rotation intervals (using the adapter plate)

Screws and nuts included

Electrical connection Connection via Power Rail

Possibility of serial connection of posts

Cable size In and out of the post: Max 25 mm²

Up to the Charging Robots: 6 mm²

Safety instructions

Read the entire manual carefully before installing and operating the product. Observe the following instructions:

Safety instructions for the installation


- This product shall only be installed, repaired or serviced by an authorised electrician. All applicable local, regional and national regulations for electrical installations must be respected.
- Danger to life due to high electrical voltage. Never make any changes to components or connecting cables.
- The installation must not be carried out in the vicinity of flammable, explosive media, flood areas (underground car park) or areas where there is a danger of flowing water.
- The product must be installed on a permanent location.
- The terminals in the Backplate are energised when the power circuit is closed and must never be in direct contact or in contact with anything other than the plug-in electronics (Chargeberry).
- Depending on the type of installation, official authorisations may be required prior to installation.

Safety instructions for operation

- Danger to life due to high electrical voltage. Never make any changes to components or connecting cables.
- Always have the prescribed maintenance, installation and any repair work carried out by an authorised electrician.
- Never extinguish the product with water. Never clean it with running water.
- Do not immerse the product in water or other liquids.

- It is advisable to have an extra protection around the post when mounted in an open parking space.
- This product is not intended for use by persons with reduced physical, mental or sensory capabilities (including children) or persons without knowledge of the product.
- Make sure that children do not play with the product.
- Do not use extension cords or unapproved adapters in combination with the product.
- Even if the Charging Robot is designed to withstand normal weather conditions, we recommend protecting it from direct sunlight or exposure to extreme weather conditions.
- Do not use the product near strong electromagnetic fields or in the direct vicinity of radio telephones.

Common parts




Common parts

Adapter plate

Attach the foundation of the column to the adapter plate with 4 socket head screws. Recommended torque is 30-40 Nm.

INFO! It can be mounted in 45° increments to get the correct direction.





9

1-Way



Parts

Mounting plate o o o o

1-way blind cover




Screws



Plate and cover

Attach mounting plate and blind cover to the column with 3 flat head screws each (6 screws total).

NOTICE! Make sure the top end of the column is sealed with a plastic cap.








2 Backplate

Thread the cable through the hole in the column and the Easee charger backplate before attaching it with 4 rounded head screws.







2-Way



Parts

Mounting plates






Screws



7 Plates

Attach the mounting plates to the column with 3 flat head screws each (6 screws total).

NOTICE! Make sure the top end of the column is sealed with a plastic cap.








2 Backplates

Thread the cables through each hole in the column and the Easee chargers backplates before attaching them with 4 rounded head screws (8 screws total).






3-Way / 4-Way




Parts



Bottom frame


Slide the bottom frame over the column and fasten it to the lower threaded hole with 1 flat head screw on each side (2 screws total).





Top frame

Attach the top frame to the top two threads using 2 flat head screws on each side of the column (4 screws in total).






3 Top plate

Cover the top frame with the top plate and fix it with 4 rounded head screws.

NOTICE! Make sure that all cables are pulled through the column holes (2 on each side) before attaching the chargers backplates.






4 First 2 chargers

Now attach the first 2 Easee chargers backplates to the sides perpendicular to the column openings with 4 rounded head screws each (8 screws total).


NOTICE! Pull the cable through the hole in the backplates before attaching them.



5 Last charger and cover

If you are installing a 3-way setup, attach the last backplate to one of the open sides and close the other one with the blind cover.


Before attaching the blind cover, the shielding tab must be flipped up in order to mount the blind cover plate with 4 rounded head screws.



5 Last 2 chargers

If you are installing a 4-way setup, attach the last 2 Easee chargers backplates to the column with 4 rounded head screws each (8 screws total).

NOTICE! Before installing the electronics in the backplates, they must all be programmed - please check the installation guide that came with the Charging Robots.





Power Rail

Power Rail

Before connecting

The Power Rail is a connection box that allows multiple charging posts to be connected in series.

Please pay attention to the earthing system of the charging post, which is described carefully in the following pages.



WARNING! The Power Rail is a product to be installed by an authorized electrician, and a declaration of conformity must always be provided upon completion by your installer.




WARNING! Turn off the power before beginning the wiring. Use extreme caution and follow instructions carefully.

Power Rail

Ground connection plate


Before installing the Power Rail make sure to apply the ground connection plate. The plate is essential for connecting the post to the protective earth (PE).

 Make sure the top PE terminal screw is open, then wedge the end of the plate into the terminal from the back. The ground connection plate should lie flat to the plastic housing.



- Insert the serrated washer on the rod inside the column.


 It should be placed between the metal column and the Power Rail.
- 3. Slide the Power Rail with the ground connection plate inside the column and latch the bottom of the rail into the catch.



4. Fasten the grounding nut with the spring washer on the rod

NOTICE! In order to complete the PE connection, the grounding nut has to be fastened and the top PE terminal screw has to be tightened (regardless of whether there is a wire in it or not).

Important! Do not forget this step!





2 Power Rail Terminals

The ground connection plate connects the entire leftmost lane to the metal column, so it is very important that this lane is **only** used for PE connections.

We recommend using the two lower terminal sets for the main power cables.

One set of terminals is used for power in and the other is used for power out, if you want to connect another charging post on the same cable. Wire size up to 25mm².






Power in / out

We recommend using the two upper terminal sets for the charger cables.

For a single charger, only one set of terminals is used, for two chargers, both sets of terminals are used, and for three or four chargers, two wires have to share a terminal. Wire size up to 6mm².




3 Wiring

The Power Rail has 5 lanes. This allows support for TN, IT and TT three and one phase electrical grids.

- Strip the cable cores by 12 mm. If the cable has flexible conductors, it is recommended to use cable end sleeves on all wires
- 2. Tighten the screws with a torque of 5 Nm.

NOTICE! Terminations should be visually and mechanically inspected before mounting the side panel.



Wiring


TN network

TN is the most common grid type in Europe. It uses five conductors to provide both 230 V and 400 V. This makes it very efficient and therefore the preferred grid type for charging electric vehicles.


NOTICE! Depending on the time of installation and national standards, the colours of the cables can vary from the illustration below. Therefore, please make sure that the conductors are correctly terminated before applying power.

NOTICE! The charger is designed for a TN grid type with 5 lead cable.

TN 1-phase



TN 3-phase




Wiring

IT/TT network


IT and TT grid systems are mostly used in Norway and Albania, but it can also be found in Belgium, France and Spain. These systems have no neutral connector and use only 4 conductors. Therefore they can only provide 230 V (across the phases).


NOTICE! Depending on the time of installation and national standards, the colours of the cables can vary from the illustration below. Therefore, please make sure that the conductors are correctly terminated before applying power.

IT/TT 1-phase




IT/TT 3-phase





4 Side panel

After connecting all wires to the Power Rail, it is time to mount the side panel with the 4 rounded head screws.





Practical details

Foundation	This charging post usually needs a mechanical foundation to be installed. The adapter plate is compatible with most c/c 160 mm foundations. We recommend foundations similar to Ørstafundament. In some situations, it is also possible to use the smaller base of the column directly without the adapter plate, in this case
	using a 80 x 80 center to center footprint.
Screws	For all the flat and rounded head screws we recommend 7-9 Nm of torque.
Returns and complaints	Contact your distributor or Easee Customer Support regarding the return and complaint of your product.
Customer support	Download the latest manuals, find answers to frequently asked questions and useful documents and videos for your product at easee.support .

THIS DOCUMENT CONTAINS INFORMATION THAT IS SUBJECT TO CHANGE WITHOUT NOTICE.

The latest version of this publication can be downloaded at http://easee.support

No part of this publication may be reproduced or transmitted in any form or by any means, electronic or mechanical, including, but not limited to, copying, recording, retrieving data, or computer networks without the written permission of Easee AS.

Easee and all other Easee product names and slogans are trademarks or registered trademarks of Easee AS. Easee products can be protected by one or more patents.

All other products and services mentioned may be trademarks or service marks of their respective owners.

Illustrations of the product and user interface are exemplary and may differ from the actual appearance.

October 2020 - Version 1.01 © 2018-2020 by Easee AS. All rights reserved.





Easee AS Grenseveien 19 4313 Sandnes, Norway