



INSTITUT TECHNOLOGIQUE

# INSTITUT TECHNOLOGIQUE

## FCBA

### Fire Laboratory

10 rue Galilée - 77420 Champs-sur Marne

Laboratory approved by the Ministry for the Interior

JO of February 10, 2007

## OFFICIAL REPORT OF CLASSIFICATION OF FIRE PERFORMANCE

### Of A MATERIAL ENVISAGED IN ARTICLE 5

### DECREE OF November 21, 2002

N°

Page 1

et 1 annexe de 4 pages.

Valid 5 years as from January wednesday the 26th, 2022

Material presents by : Filmolux France  
5 rue Benjamin Franklin  
94370 Sucy en Brie

Trade mark: LUXprint Paper 230g M1

#### Summary description

Kind of textile papier  
Composition 53,5% chemical pulp + 25% pigments and fillers + 13% binders + 8,5%  
flame retardant agent  
Mass per unit area 230 g/m<sup>2</sup> - épaisseur : 0.25 mm  
Kind of Fire retardant application ignifugeant 20 g/m<sup>2</sup>  
Color white

Nature of the test : Electrical burner test

Classification : M1

Observations :

Durability of the classification (Article 5 de l'annexe 2) 12 months starting from the implementation in a regulated building

Usual term Walls hung covering, sheers, curtains,... Cleaning conditions No cleaning

Taking into account the criteria resulting from the tests annexed described in the test report N FE 21-0147-0859

This official report attests only characteristics of the sample submitted for testing and does not prejudice similar characteristics of products. It thus does not constitute a certification of products within the meaning of the L.115-27 article of the code of the consumption and the law of June 3rd, 1994

NOTE: The integral reproductions and by photocopy of this official report of classification are only authorized or the official report unit of classification and report of annexed test. These conclusions relate only to the resistance / reaction to fire performance of the element that is the subject of the present classification report. They do not prejudice, in any case, other performances related to its incorporation to a work "


"Not legally acceptable for any use under the pretence of the article AM 18 (Decree of March 6th, 2006) for upholstered seat"

Champs-sur-Marne, le mercredi 2 février 2022  
Technicien d'essais du Laboratoire Feu

Responsable Technique du laboratoire Feu  
du Pôle Ameublement

Siège social  
10 rue Galilée  
77420 Champs-sur-Marne  
Tél + 33 (0)1 72 84 97 84  
www.fcba.fr  
Siret 775 680 903 00132  
APE 7219 Z  
Code TVA CEE : FR 14 775 680 903

Bilal HAMILA



Clotilde ETIEMVRE

Institut technologique FCBA - Forêt Collinoise - Bois - construction, Ameublement