

## ASSEMBLY INSTRUCTION FOR MINERAL WOOL PIPE SECTIONS

Pipe section insulation has fabric-made longitudinal cut which could be opened thus facilitating the insulation of the pipe. Pipe insulation faced with reinforced ALU foil has longitudinal section with overlapping facing with attached self-adhesive band. It is necessary to clean the ALU facing with alcohol prior mounting, then remove the protective tape from the self-adhesive band, press the longitudinal section and stick. The connection of the two segments is made by aluminum sticker. Aiming to achieve stronger fixture, the ALU sticker should be placed each 0.5 m along the length of the whole pipe.

### Important Environmental Note!

At the moment it is impossible for the contractors to return installation spillage to Chemical Products Ltd. factory as we have no recycling system yet in Bulgaria. We recommend you to check this opportunity in the country of installation.

We also recommend you in order to minimize installation spillage to carefully disassemble old insulation which could result in over 70% reuse of the existing insulation as defective insulations to be recycled in granulate used in the building for wall insulation.

As part of our Environmental Protection Policy, we use all generated industrial waste of mineral stone wool in new products like IsolFill – loose –fill mineral wool products for in-situ installations in lofts, masonry cavities and frame constructions.