



Permit Processing Instructions

1. Complete Form and Sign at bottom of Page 2
2. Save the form as your Company Name
3. Email to firemarshal@dfwairport.com or Fax to 972-973-3453
4. Work cannot begin until you have received a signed and approved permit from our office.



LP Storage



DFW Airport Fire Prevention
3600 S 20th Ave
DFW Airport, Tx 75261
Phone: 972-973-3580
Email: FireMarshal@dfwairport.com

Issued To

Name:
Business Name:
Business Address:
Contact Number:
DCC Permit #:

Application Date:

Permits#

Type of work and Dates:
Work Location:

Current LP Storage Guidelines

1. LP-gas containers shall not be stored inside buildings.
2. LP-gas containers shall be stored in proper cages, which shall be locked.
3. LP-gas storage areas shall be protected from vehicle impact.
4. LP-gas storage areas shall be separated from smoking areas by a minimum of 25 feet.
5. LP-gas containers in storage shall be located in a manner that minimizes exposure to excessive temperature rise, physical damage or tampering.
6. LP-gas containers in storage shall be positioned with the pressure relief valve in direct communication with the vapor.
7. LP-gas containers shall not be located within 10 feet of exit access doors, exits, stairways or in areas normally used, or intended to be used, as a means of egress IN TERMINAL BUILDINGS. At other locations, this distance shall be no less than 5 feet.
8. LP-gas containers shall not be stored within 10 feet of combustible materials.
9. Empty LP-gas containers shall be considered as full containers for the purpose of determining maximum allowable quantities of LP-gas.
10. LP-gas containers that are not connected for use shall not be stored on roofs.
11. LP-gas containers shall not be stored in a basement, pit or similar location where heavier-than-air gas might collect.
12. LP-gas container valves shall be protected by screw-on type caps or collars which shall be securely in place on all containers stored regardless of whether they are full, partially full or empty. Container outlet valves shall be closed or plugged.



Applicant Signature

Issuing Official Signature

ID #

