

# **TECHNICAL NOTICE**

**FOR THE DOCUMENTS**

**ABM, KBM, TBM and TBV**

**Edition 2, 2021-11-01**

The Swedish Nuclear Power Companies have jointly produced this document.  
Any revision of this document must be approved by mutual consultation between the  
companies.

Approved:

Anders Magnusson FKA, Erik Lindén OKG and Fredrik Olvmark RAB

Licensee administrators of the PAKT-documents

**TABLE OF CONTENTS**

<b>1</b>	<b>INTRODUCTION.....</b>	<b>4</b>
<b>2</b>	<b>DECLARED CHANGES TO ABM EDITION 5.....</b>	<b>4</b>
<b>2.1</b>	<b>2.4.2 Analysis of deficiencies .....</b>	<b>4</b>
<b>2.2</b>	<b>2.4.5.1 Deficiencies in mechanical equipment which shall be reported to SSM.....</b>	<b>4</b>
<b>3</b>	<b>DECLARED CHANGES TO KBM EDITION 8.....</b>	<b>4</b>
<b>4</b>	<b>DECLARED CHANGES TO TBM EDITION 8.....</b>	<b>4</b>
<b>5</b>	<b>DECLARED CHANGES TO TBV EDITION 2.....</b>	<b>4</b>
<b>5.1</b>	<b>4.4.1 Designations for extent of inspection and supervision.....</b>	<b>4</b>

**LIST OF REVISIONS – TECHNICAL NOTICE**

<b>Edition</b>	<b>Reason for revision</b>	<b>Applicable pages</b>	<b>Date</b>
1	New document	--	2018-01-23
2	Earlier changes to KBM and TBM are incorporated in respective document ed. 8. Additional changes to ABM.	Entire document See markings	2021-11-01

## 1 INTRODUCTION

This technical notice constitutes the official addendum to the power plant common application documents ABM, KBM, TBM and TBV prepared by the Swedish licensee.

The technical notice constitutes a clarification, correction or change in the wording of the ordinary PAKT-document. The formulations will be processed in each PAKT-document upon future updates.

## 2 DECLARED CHANGES TO ABM EDITION 5

### 2.1 2.4.2 Analysis of deficiencies

Analysis of deficiencies shall be reviewed by an accredited inspection body in quality class 4 inspection class C, which is now referred to as quality class 4 AFS class –.

### 2.2 2.4.5.1 Deficiencies in mechanical equipment which shall be reported to SSM

Quality class 4 inspection class A and B are now referred to as quality class 4 AFS class A and B.

## 3 DECLARED CHANGES TO KBM EDITION 8

No clarifications, corrections or changes exist.

## 4 DECLARED CHANGES TO TBM EDITION 8

No clarifications, corrections or changes exist.

## 5 DECLARED CHANGES TO TBV EDITION 2

### 5.1 4.4.1 Designations for extent of inspection and supervision

Section is changed as follows:

- E Inspection and/or testing<sup>1</sup> to be carried out and documented in-house (even by external) on their own responsibility.<sup>2</sup>
  - L Testing to be carried out and documented by Accredited Laboratory.
  - T Inspection and/or testing to be carried out and documented by the manufacturer/purchaser. Manufacturers or purchasers requirements.
  - B Activity to be supervised, verified, reviewed and/or approved by the licensee/purchaser.
  - Q Independent review and inspection to be carried out and/or approved by the inspection organisation of the licensee.
- 1) Testing carried out in conjunction with manufacturing of material and shapes may be carried out as in-house inspection provided that the manufacturer possess and adheres to a quality system certified by an Accredited Notified Body according to KBM 1.8.3.
  - 2) Personnel performing work must not inspect and approve their own work. Personnel performing in-house inspection must have the necessary expertise.