

## S Plan

Wiring support document



## **IMPORTANT TO NOTE**

- **Electricity can kill, safe electrical isolation must be adhered to**
- All mandatory electrical checks must be carried out in line with current regulations and specific attention should be drawn to your companies Safe Working Practices
- All service checks required under regulation 26.9 should be followed at all times when working on gas appliances



- Find brown wire on central heating plan valve 2
- Linked in to the brown wire will be another wire. This should be the 'calling' from the room thermostat
- This is the room thermostat cable
- There are other wires in the cable, one of which is normally the neutral 4
- The other wire will be the 'common'.
- Linked into the 'common' will be central heating on from the programmer
- Remove the room thermostat cable and link the central heating on wire and the brown wire together
- The wiring has now been installed for Hive in the wiring center

