



From Kerren Ven <KVen@fairfieldcity.nsw.gov.au>
Date Tue 17/12/2024 2:40 PM
To Rebecka Groth <rebecka.groth@dpie.nsw.gov.au>

Hi Rebecka,

Last week I uploaded Council's letter on the Portal and in the letter it mentioned that comments related to stormwater management will be provided when available. Our Development Engineers have provided the below comments:

Stormwater Drainage

The top of kerb level shall be clearly shown at each connection point to Council's underground drainage system to demonstrate there will be no surcharge within the subject site due to any blockage in street drainage system.

Adequate details shall be provided to ensure the OSD storage is above the top of kerb level at connection points.

Let me know if you have any questions. Thank you.

Kind regards,

Kerren Ven

Senior Strategic Land Use Planner
Strategic Land Use Planning | City Strategic Planning

02 9725 0878 | kven@fairfieldcity.nsw.gov.au

Customer Service: 02 9725 0222 | PO Box 21 Fairfield NSW 1860

www.fairfieldcity.nsw.gov.au
mail@fairfieldcity.nsw.gov.au



*We acknowledge the Cabrogal of the Darug nation who are the Traditional Custodians of this Land.
We also pay our respect to the Elders both past, present and emerging of the Darug Nation.*



Thank you is enough, no need for gifts.

