

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Mannington Mills, Inc

75 Mannington Mills Road, P.O. Box 30, Salem, NJ, United States

For the following product(s):

Rubber - Tile, Sheet, Wall Base, and Accessories:

Mannington: ColorScape, ColorSpec, Mannington ColorFields Rubber Sheet and Tile Flooring, Mannington ReSet (recycled crumb rubber flooring), Mannington Rubber Tile, Open Range Rubber Planks, Stair Treads, Risers, Stringers, Edge Effects, Rubber Wall Base, Teles, Teles Stair Treads, TS Rubber Wall Base, TP Rubber Wall Base, Transportation Rubber

Burke: Burke Rubber Wall Base, IdealBase, Stair Treads, Stringers, Risers, Cove Base, TS Rubber Wall Base, TP Rubber Wall Base



The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Between 0.5 – 5.0 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-01875

Valid from: October 1, 2022 to September 30, 2023

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA