

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Mannington Mills, Inc

75 Mannington Mills Road, P.O. Box 30, Salem, NJ, United States

For the following product(s):

Vinyl Tile:

Adura Max, Adura Apex, Adura Max Prime, Adura Rigid, City Park, Enduring, Enduring SPC, Foundations SPC, Mannington Crown Collection, Mannington Essentials, Parkland, Parkland 20 USA, Parkway Rigid, Realta SPC, The Avenues Collection

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-04330

Valid from: October 1, 2022 to September 30, 2023

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI National Accreditation Board

ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION
BODY



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA