

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Mannington Mills, Inc

75 Mannington Mills Road P.O. Box 30, Salem, New Jersey 08079, United States

For the following product(s):

Vinyl Tile:

Adura Max, Adura Apex, Adura Pro SPC, Adura Rigid, City Park, Cresta, Mannington Crown Collection, Nexcore, Parkland 20 USA, Parkway Rigid, Realta SPC

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-105 Version 4.2 – 2023

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-04330

Valid from: October 01, 2025 to September 30, 2026

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI National Accreditation Board

ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION BODY



A handwritten signature in black ink, appearing to read "D. Phillips".

Diana Kirsanova Phillips, Chief Assurance Officer,
SCS Global Services