


SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Object: Hood
Size [mm]: w = 3000 h = 600 d = 1200

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.99
125	1.7
250	3.33
500	3.99
1000	4.81
2000	5.44
4000	6.11
N₁₀ = 2.5	



ORIGINAL TEST REPORT

SP report 10188019

DATE OF TEST

2013-11-04