

ENGINEERING BULLETIN

Subject: Exalt and Gallant Boiler Generator Power

Date: 5/18/2021

Exalt and Gallant boilers are capable of being powered via electric generator. The requirements of the power supply are:

- 98 Vac to 126 Vac
- 47Hz to 65Hz
- Boiler needs to be properly grounded

Please contact technical support at techsupport@idealheatingna.com or 800-411-9999 x575 with any questions.