



SMITH EMERY LABORATORIES

An Independent Commercial Testing Laboratory, Established 1904

306 N 6th Street ▪ P.O. Box 226 ▪ Oakesdale, Washington 99158-0226
Phone: 509-285-4337 ▪ Fax: 509-285-4354

Fabricator Certificate of Recognition


AVALON INTERNATIONAL ALUMINUM, LLC 21451 SW 108th AVENUE TUALATIN, OREGON 97062

Has been approved as a Fabricator of 90 minute fire rated aluminum door frames and 45 minute fire-rated aluminum doors, frames, and glazing systems - borrowed light and sidelight assembly with glazing and Frame and Steel Clad frame assemblies and has demonstrated substantial compliance with Smith Emery's quality requirements for recognition as an approved fabricator as noted and has been recognized under the 1997 Uniform Building codes section 1701, IBC Section 1704, and under the requirements and guidelines of AC-10, AC-98, ASTM-E-119 and ASTM-E-152 Fire test for doors, UBC Standard 43-2 fire test assemblies, NFPA-252 and NFPA-257 Standard method for fire test of door assemblies, Underwriters Laboratories Standard UL-9, UL-10b, UL-10c, & UL-1784 S Fire test of door assemblies, UBC-1997, section 7-2, UL report Number R18465 Gasket Edge sealing report of certification. Warnock Hersey International test report WHI-495-0695, B.I. Report No. 07-086-1966.

**This listing/recognition is valid for One year
January 1, 2026 through January 1, 2027**

Avalon International fabrication processes and procedures covered by this certificate are conducted in accordance with the aforementioned Codes; the Fabricator's approved Quality Manual, Previous Test results, and facility procedures. Annual facility audits are conducted by Smith Emery, to monitor the fabricator's quality system and production processes. This recognition is limited to the fabrication processes and procedures only. This recognition does not include the product, or the design or performance characteristics of the fabricated product.

Certification Number: SE-43623-2026

Approved by:  Date: December 31, 2025
William J. Tate Jr, Agency Director
Smith Emery Laboratories AA-554



William J Tate Jr.
QMS Master Auditor
Certificate No: 104685