



Daily Pool Log Template

Complete

Score	4.2 / 12 (35%)	Flagged items	1	Actions	0
Pool Name	Outdoor Olympic Pool				
Month	February				
Year	2023				
Pool Operator/Pool Manager	Johan Johnston				
Location	5178 Arvinels Ave, San Diego, CA 92117, USA (32.8398998, -117.1753997)				
Conducted on	3 Feb 2023 08:00 PST				

Flagged items

1 flagged

Daily Pool Log / Pool Log / Pool Log 1

• pH

6.8

Daily Pool Log	1 flagged, 4.2 / 12 (35%)
Pool Log	1 flagged, 4.2 / 12 (35%)
Pool Log 1	1 flagged, 4.2 / 12 (35%)
• Date and Time	3 Feb 2023 08:00 PST
• Temperature (F)	76
• Water Clarity	Clear
• Disinfectant	Stabilized Chlorine (Tablets or granules containing Dichlor or Trichlor)
Free Chlorine (ppm)	4 From 0 to 11
• Combined Chlorine (ppm)	0.20000000298023224 From 0 to 1
Conduct superchlorination by adding ten times the combined chlorine ppm	
• Total Chlorine (Free Chlorine + Combined Chlorine)	4.2
• pH	6.8
Raise the pH, add soda ash (sodium carbonate)	
• Flow GPM	73
• Bather Load	8
Sign Off	
Comments	Added soda ash and pH is now 7.6
Based on the photo attached, we're using a new tool in collecting pool water samples to check the pH level.	
	
Photo 1	
Name and Signature	

Johan Johnston
3 Feb 2023 09:01 PST

Media summary



Photo 1