



General Construction Risk Assessment Template

Boards and Nails Corporation / Mateo Roman / 20 Feb 2026

Complete

Score	0 / 0 (0%)	Flagged items	0	Actions	1
--------------	------------	----------------------	---	----------------	---

Company / Site

Boards and Nails Corporation

Inspector

Mateo Roman

Date & Time

20.02.2026 12:00 PST

Location

Downtown Berkeley, Berkeley, CA,
USA
(37.86999730000001,
-122.2678788)

Actions

1 action

Completion / Completion

Additional recommendation

I was told that one crane malfunctioned during the shift. Please make sure all equipment is checked properly before and after the shift to avoid incidents.

To do | Priority: Medium | Due: 27.02.2026 14:00 PST | Created by: SafetyCulture Staff

SOP Update

Add to the existing SOP that a pre-start check on all equipment will be required.

Risk Audit: Hazards

	Select equipment/process involved	Brief description	Risk rating
1	Working at Heights	Looked like a makeshift scaffold - but overall dangerous. Planks must be secured and tied to beams and braces.	High
2	Walkways	Poor housekeeping - debris, dust/ trash should be cleared off the walkways to avoid obstruction.	Medium
3	Power Operated Tools & Equipment	Damaged equipment such as this should be kept in a proper storage area and must be replaced as soon as possible to avoid any injuries or further risks.	High
4	General Work Environment	Inadequate lighting in work areas. Terrible.	High
5	Hand Tools & Equipment	This is just too messy. Tools must be grouped properly. Some are rusty and not healthy for use. This should not be exposed and must be properly stored in a container/ handheld toolbox.	Medium
6	Electrical	Messy wiring and is a trip hazard. Please fix this within the day or ASAP.	Medium
7	Personal Protective Equipment	One employee on the scaffold located on the left wing refused to wear his goggles as it was too dirty and clouded his vision when working. I understand his reason and we should provide him with goggles in good condition instead ASAP.	High

Completion

1 action

Completion

1 action

Additional recommendation

I was told that one crane malfunctioned during the shift. Please make sure all equipment is checked properly before and after the shift to avoid incidents.

To do | Priority: Medium | Due: 27.02.2026 14:00 PST | Created by: SafetyCulture Staff

SOP Update

Add to the existing SOP that a pre-start check on all equipment will be required.

Inspector's Full Name & Signature



Mateo Roman
24.02.2026 12:39 PST