



OSHA PPE Compliance Audit Checklist

Jace and Jin Construction / Jowe Artarlen / 14 Feb 2023

Complete

Score	13 / 17 (76.47%)	Flagged items	4	Actions	0
Site conducted	Unanswered				
Client / Site	Jace and Jin Construction				
Location	5000 Estate Enighed, Independence, KS 67301, USA				
Conducted on	14 Feb 2023 08:26 PST				
Prepared by	Jowe Artarlen				

Flagged items

4 flagged

Audit / PPE Inspection

Are your work sites regularly checked for the need for PPE? (Head, eye, face, hand, or foot protection)

No

Site inspections for PPE needs were conducted once a month

Audit / PPE Inspection

Are protective gloves, aprons, shields, or other means provided and required where employees could be cut or where there is possible exposure to corrosive liquids, chemicals, blood, or other potentially infectious materials?

No

This employee is not wearing appropriate PPE. Welding task has a high risk getting burns and other physical injuries



Photo 1

Audit / PPE Inspection

Are approved respirators provided for regular or emergency use where needed?

No

Respirators are not available on site

Audit / PPE Inspection

Is ear protection provided in areas where sound levels exceed those of the OSHA noise standard?

No

There are no ear protection available on site



Photo 2

Audit	4 flagged, 13 / 17 (76.47%)
PPE Inspection	4 flagged, 13 / 17 (76.47%)
Are your work sites regularly checked for the need for PPE? (Head, eye, face, hand, or foot protection) Site inspections for PPE needs were conducted once a month	No
If the need for PPE is determined, are employers providing employees properly-fitted equipment?	Yes
Have the employees in the hazardous areas been trained on OSHA PPE standards? (Using what items, in what circumstances, as well as when and how to wear it and properly adjust it) All employees attended proper training	Yes
Are protective goggles or face shields provided and worn where there is danger of flying particles or corrosive materials?	Yes
Are approved safety glasses required to be worn at all times in worksites that pose a risk of eye punctures, abrasions, contusions, or burns?	Yes
Are employees who wear corrective lenses (glasses or contacts) on worksites with harmful exposures required to wear only approved safety glasses, protective goggles, or use other medically approved precautionary procedures?	Yes
Are protective gloves, aprons, shields, or other means provided and required where employees could be cut or where there is possible exposure to corrosive liquids, chemicals, blood, or other potentially infectious materials? This employee is not wearing appropriate PPE. Welding task has a high risk getting burns and other physical injuries  Photo 1	No
Are hard hats inspected periodically for damage to the shell and suspension system?	Yes
Is appropriate foot protection required where there is the risk of foot injuries from hot, corrosive, poisonous substances, falling objects, crushing or penetrating injuries?	Yes
Are approved respirators provided for regular or emergency use where needed?	No

Respirators are not available on site

Is all PPE maintained in a sanitary condition and ready for use?

Yes

Are eye wash facilities and quick drench showers available within the worksites where employees are exposed to dangerous corrosive materials?

Yes

Is necessary special equipment available for electrical workers?

Yes

Are food and beverages consumed in areas with no hazardous exposure to toxic materials, blood, or other infectious materials?

Yes

Is ear protection provided in areas where sound levels exceed those of the OSHA noise standard?

No

There are no ear protection available on site



Photo 2

Are safe work procedures and PPE provided and used when cleaning up spilled toxic or hazardous materials and liquids?

Yes

Are appropriate safe work procedures in place for disposing of or decontaminating PPE after hazardous exposure?

Yes

Recommendations

List recommendations here

1. Conduct regular inspection to maintain safe workspace
2. Always ensure all employees wear appropriate PPE before commencing work
3. Respirator and ear protection should be available on site

Completion

Full Name and Signature of Inspector



Jowe Artarlen
14 Feb 2023 08:28 PST

Media summary



Photo 1



Photo 2