

Upper Trinity provides safe and reliable drinking water service to more than 25 communities and utilities in Denton and Collin Counties. We endeavor to provide water that meets or exceeds all Safe Drinking Water Standards established by the Environmental Protection Agency (EPA).

Upper Trinity has two water treatment plants - the Taylor plant in Lewisville and the Harpool plant in northeast Denton County. The treatment process at both plants assures that our Customers receive the best drinking water - for both taste and health.

This annual Consumer Confidence Report (CCR) summarizes the quality of drinking water provided to our Customers. The report is based on analysis of data from numerous EPA required tests. The EPA requires all water systems to test for over 100 specified contaminants. The chart on the inside lists all of the federally regulated or monitored contaminants detected in the Upper Trinity's drinking water.

For more information, please contact:

Upper Trinity Regional Water District
P.O. Box 305
Lewisville, TX 75067
972-219-1228

www.utrwd.com



Taylor Water Treatment Plant
Lewisville, Texas

Find Us



**Denton County
Greenbelt Plan**
For the Future



DentonCountyGreenbeltPlan.com


WaterMyYard.org

Tom Harpool Water Treatment Plant
Aubrey, Texas



2017

CONSUMER CONFIDENCE REPORT



Drinking Water Quality Report for
Members & Customers Served by
Upper Trinity Regional Water District

**Yes! Our Water Meets or
Exceeds all State and Federal
Standards.**

WATER FROM UPPER TRINITY REGIONAL WATER DISTRICT CONSTITUENTS DETECTED FOR 2017

Date	Substance	Maximum Amount in UTRWD Water	Range in UTRWD Water	MCL	MCLG	Possible Source
------	-----------	-------------------------------	----------------------	-----	------	-----------------

9/26/2017	Barium (ppm)	0.043	0.032 - 0.043	2 ppm	2 ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
2nd QTR	Bromate (ppb)	8.80	1.1 - 8.8	10 ppb	0	Byproduct of drinking water disinfection
May-17	Chloramines (ppm)	3.69	3.19 - 3.69	4.0*	4.0^	Water additive used to control microbes
2/2/2017	Cyanide (ppm)	0.0747	ND - 0.0747	0.2 ppm	0.2 ppm	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories
2/2/2017	Fluoride (ppm)	0.192	0.169 - 0.192	4 ppm	4 ppm	Water additive, erosion of natural deposits, discharge from fertilizer and aluminum factories
2/2/2017	Nitrate (ppm)	0.622	0.157 - 0.622	10 ppm	10 ppm	Fertilizer runoff, septic tanks, wastewater plant effluent, animal waste runoff.
9/26/2017	TOC (ppm)	4.38	2.77 - 4.38	TT	N/A	Naturally present in the environment
May-17	Turbidity (NTU)	0.29	0.03 - 0.29	TT	N/A	Soil runoff.

9/26/2017	Total THM's (ppb)	43	13.2 - 43	80 ppb	N/A	Disinfection by-product.
9/26/2017	Total HAA's (ppb)	21	7.8 - 21	60 ppb	N/A	Disinfection by-product.

2/2/2017	Gross Beta Emitters (pCi/L)	ND	N/A	50	0	Decay of natural and man-made deposits.
9/16/2015	Combined Radium (pCi/L)	1.5	N/A	5	0	Erosion of natural deposits

6/27/2016	Atrazine (ppb)	0.2	N/A	3 ppb	3 ppb	Herbicide runoff.
6/27/2016	Simazine (ppb)	0.06	ND - 0.06	4 ppb	4 ppb	Herbicide runoff.

<p>MCL- Maximum Contaminant Level: The highest level of a contamination that is allowed in drinking water.</p> <p>MCLG-Maximum Contaminant Level Goal: The level of a contamination in drinking water below which there is no known or expected risk to health.</p> <p>MRDL-Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of disinfectant is necessary for control of microbial contaminations.</p> <p>MRDLG- Maximum Residual Disinfectant Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of disinfectants use to control microbes.</p> <p>NTU: Nephelometric turbidity units. A measure of turbidity in water.</p> <p>pCi/L: Picocuries per liter. A measure of radioactivity in water equal to 10^{-12} curies. Quantity of radioactive material producing 2.22 nuclear transformations per minute.</p> <p>ppb: Parts per billion. One part per billion is roughly equal to one packet of artificial sweetener sprinkled into an Olympic-size swimming pool.</p>	<p>ppm: Parts per million. One part per million approximates one packet of artificial sweetener sprinkled into 250 gallons of iced tea.</p> <p>TT- Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.</p> <p>Turbidity: A measure of the clarity of water. While turbidity has no known health effects, it can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing symptoms such as nausea, cramps, diarrhea, and associated headaches.</p> <p>TOC-Total Organic Carbon: Has no known health affects. However, TOC provides a medium for the formation of disinfection by-products. These include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these by-products in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.</p>
--	--

Este reporte incluye informacion importante sobre el agua para tomar. Para asistencia en espanol, favor de llamar al telefono (972-219-1228)

For opportunities to participate in decisions that may affect water quality, Board Meetings are held on the first Thursday of the month, starting at 1pm. Additional resources can be found at www.utrwd.com or by calling 972-219-1228